

SCANNED

FIELD CORRECTION NOTICE

LOCATION 184 Maumee Avenue East

PERMIT NO. S-248

ISSUED TO Take N. Boko ; Bob Hicks
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO [Signature]

Upon inspection, violations of the 1884 NEC

Sec. 210-7 ; 250-45-D
600-11 ; 400-8 were in evidence.

The following orders are hereby issued for their correction: Circuit feeding Electrical portable sign shall be GFCI protected. Grounding shall be continuous. Cord shall not be run through doorway. Flashing lights are prohibited.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE Immediately

DATE 09 JAN 86 4:25 PM

BY Paul E Buehner
INSPECTOR

FIELD COPY

PROJECT RECORD FORM

JOB NUMBER _____

DATE	REMARKS
2/10/85	184 WEST OF KALIFORNIA MALMEE AVENUE EAST
"	FRESH FOODS (PIZZAS)
"	TAKE-OUT ONLY
"	FRESH FOOD STORAGE
"	NO COOKING
"	DRIVE THRU - ONLY
"	NO PARKING
"	GB DISTRICT
"	USE GROUP "M".
"	BOB HICKS WALDEN
"	337-0117
"	2x4 CONSTRUCTION THROUGHOUT
"	SKETCH OF EXISTING BUILDING PROPOSED CHANGES
"	WOOD COUNTY COURT HOUSE
"	NEEDS SIGN PERMIT
"	<i>[Signature]</i>
"	
"	
"	
"	

