

BUILDING CONSTRUCTION PERMIT

Owner Name ...
Address ...
Builder Name ...
Address ... Tel. ...

Lot Information:

Street No. ...
Lot ... Subdivision ...
Lot Dimensions ... Lot Area ... Sq. Ft.
Yard Set Back: Front ... Rear ...
Side ... Side ...

REPLACING ALL EXISTING 8" X 8" WOOD POST FOR STRUCTURAL SUPPORT
Sidewalk required in accordance with Ordinance No. ...

Building Information:

LOCATED IN ZONE "OB"

Residence ... Commercial ... Industrial ...
Single ... Double ... Multiple ... New Construction ... Addition ... Remodel ...
Size: Length ... Width ... No. of Stories ...
Floor Area: 1st Floor ... 2nd Floor ... 3rd Floor ... Basement ...
Unfinished Attic ... Garage ...
Foundation: Piers ... Full Basement ... Part Basement ...
FOOTERS Concrete ... Block ...
Walls: Frame ... Block ... Brick ... Other ...
Electrical Outlets: 120v ... 240v ...
Plumbing: Fixtures ... Traps ... Vents ... Heating ... Air Conditioning ...

Additional Information: This permit requires compliance with the attached ordinance ...
Date ... Applicant Signature ...

Inspection Record:

Work Started ... Foundations ... Plumbing, Heating ...
Set Back, Side Lines ... Plumbing (Rough In) ... And Air Conditioning ...
Excavation removed existing Footers to virgin soil inspected 2/27/75 by Bob ... Erecting Frame ... Roof ...
Footing ... Electrical Work ...

Comments: John Fruchey - Fire Inspector, Inform Bob Jones and Myself Ordinance No. 713 does not apply in this case. P.W.F.
ON FEB 3, 1975
Certificate of Occupancy Issued

Pink - Engineer

Inspector

Permit No. ...
Issued ...
By ... Building Inspector ...
Estimated Cost ...


Table with columns: Fees, Base, Plus, Total. Rows include Construction, Basement, Detached Garage, Plumbing, Electrical, Heating, Air Conditioning, Water Tap, Sewer Tap, Temporary Electric, Total. Total fee is \$35.00.

FLOYD G. BROWNE AND ASSOCIATES, LIMITED

CONSULTING ENGINEERS-PLANNERS

9040-MI-N-16

January 31, 1975



Mr. Pritam Arora
Building Commissioner
City of Napoleon
City Building
Napoleon, Ohio 43545

SUBJECT: PLAN REVIEW
DOUG KAUFMAN'S RESTAURANT

Dear Mr. Arora:

I have reviewed the two sets of plans transmitted herewith for structural compliance with Chapter BB 63 Places of Assembly of the Ohio Building Code and have approved the structural details for construction.

I would like to ask the question; has cutting notches into the 8" x 8" posts to receive the 2" x 8" braces been checked structurally?

If you have any questions feel free to call.

Very truly yours,

FLOYD G. BROWNE AND ASSOCIATES, LIMITED


Robert C. Jones, P.E.
Plan Reviewer

RCJ/fbh



MARION OFFICE
181 South Main Street
P.O. Box 587
Marion, Ohio 43302
614-383-2187

* NORTHWESTERN OFFICE
703 North Perry Street
P.O. Box 27
Napoleon, Ohio 43545
419-592-5771

EASTERN OFFICE
5276 Fulton Drive
Canton, Ohio 44718
216-494-3324

MEMBERS

E. B. Butler, P.E.
T. J. Dunn, Sr. P.E.
R. C. Jones, P.E.
M. L. Koehler, P.E.
S. W. Kuhner, P.E.
H. R. Lloyd, P.E.
C. R. Martin, P.E.
L. E. Rigby, P.E.
D. L. Tesmer, P.E.
C. W. Wright, P.E.

ASSOCIATES

R. M. Blank, P.E.
G. G. Geis, A.I.P.
R. L. Haas, C.E.T.
W. R. Hill, C.E.T.
J. M. Keevil, P.E.
T. Kraschinsky, Jr., P.E.
R. C. Lewis
D. E. Mackling, P.E.
A. P. Mahatekar, P.E.
J. E. Miller, P.E.
H. L. Mumaw, P.E.
F. X. Waldo, P.E.

Floyd G. Browne and
Associates, Limited is
an equal opportunity
employer


*ADDRESS REPLY TO NORTHWESTERN OFFICE



MEMO TO Mr. Pritam Arora DATE 2-3-75
SUBJECT Glen Review Jan. 75 JOB NO. _____
FROM RCJ TITLE _____

Project	Hours	Date
Calvary Baptist Church	2	1-3-75
Doug Kaufman's Restaurant	1	1-31-75

RC Jones



ENGINEERING DEPARTMENT
INTEROFFICE COMMUNICATION

Date: Jan 8, 1975

To: Engineering From: Tom Terranova

Subject: Meeting with John Allen of Allen Builders Inc.

- Re: Kaufman Restaurant - W. Maumee Ave,
- Purposed const. @ rear of bldg, pouring new footers for "I" beam cols,
- I granted Allen permission to only shore under part of bldg, and not to actually start const. until bldg. permit issued.
- I also informed Allen he had to conform to O.B.C. and to submit two copies of Elevation views, section views and material description.

Tom Terranova 1/8/75

Allen Builders - McClure Phone No. 136