

**City Of Napoleon**  
**FIELD SURVEY FORM**

**SCANNED**

Premises Address: E. Maunice + P.3 Company Name: Campbell Soap (Screen house)  
Contact Name: Mike Meringer Contact Phone No: 592-1010  
Service No: 2474 Service Size: 1" Meter No: 47190827 Meter Size: 1" Date Installed: 1-2-97  
Type of Inspection: Initial  Follow-Up  Date of Inspection: 4-28-98 Inspector Name: Charlie  
Type of Use: Industrial  Commercial  Residential  Water Main Size: 6" System Pressure 65-75 psi  
Type of Service: Domestic  Fire  Combined  Any Other Water Source: Yes  No   
If Yes, Other Type: Additional City Service  Auxiliary Source  Interconnected: Yes  No   
\*\*\*\*\*

**DOMESTIC SYSTEMS**

Type of Use: Processing  Product  Potable  Sanitary  Irrigation  Limited Area Fire   
Type of Heating: Forced Air  Electric  Solar  Boilers  Chemical Treatment: Yes  No   
Type of Cooling: Cooling Tower  Chiller  Chemical Treatment: Yes  No  Direct Conn: Yes  No   
Dishwasher: Yes  No  Eductors: Yes  No  Garbage Disposal: Yes  No  Jacuzzi: Yes  No   
Swimming Pool: Yes  No  Air Gap at Supply: Yes  No  Pumps Used: Yes  No  Capacity

**INSPECTOR COMMENTS/DIAGRAMS**

1" - Hose feed  
1 1/2" Hose feed  
used for clean up + priming pumps for drain water

**FIRE PROTECTION SYSTEMS**

System Type: Dry Spinkler  Wet Sprinkler  Dry Riser  Wet Riser  Hydrants: Yes  No   
Hydrants Self-Draining: Yes  No  Storage Provided: Yes  No  Antifreeze Legs: Yes  No   
Auxiliary Water Storage: Yes  No  Pumps Used: Yes  No  Capacity: \_\_\_\_\_ (GPM) Pressure: \_\_\_\_\_

**INSPECTOR COMMENTS/DIAGRAMS**

Please Note the large meter pit on E. Maunice, we will leave meter in place and  
valve turned off no backflow device will be required at this time

**BACKFLOW PREVENTION REQUIREMENTS**

A R.P.Z assembly needs to be installed here (Screen House)  
note: all devices to be installed shall be in horizontal position