

SCANNED

4-6-77

Addendum to Plan approval #682-77E

- 1- Electrical wiring equipment and installation shall conform to the requirements of the 1975 National Electrical Code, and to the satisfaction of the City Electrical Inspector.
- 2- Grounding of service entrance equipment - Article 250-81 N.E.C.
- 3- Bonding of service entrance equipment. Article 250-72(d) N.E.C.

Norman Howes

SCANNED

April 11, 1977

ADDENDUM TO PLAN APPROVAL
CAMPBELL SOUP COMPANY
RIVER WATER INLET AND PUMPING
STATION NO.682-77

Mr. Richard Bishop
City Manager
City of Napoleon
P.O. Box 151
Napoleon, Ohio 43545

This addendum is attached to and is a part of the plans. All items listed below shall be performed and will be incorporated into the structure.

1. Electrical wiring, equipment and installation shall conform to the requirements of Section 4101:22-69-29 of the Ohio Administrative Code and to the latest edition of the National Electrical Code.
2. Fire extinguishing equipment must comply with Section 4101:2-69-32 of the Ohio Administrative Code.

Plan Approval will be valid only upon the signing of this Addendum by the owner or his authorized representative.



Authorized Signature



Title

RCJ/fbh

City of Napoleon
Engineering Department
P. O. Box 151 - 255 W. Riverview Ave.
Napoleon, Ohio 43545

SCANNED

No. 682-77E

Date April 6, 1977

CERTIFICATE OF

- Structural Plan Approval
- Electrical Plan Approval
- Special Plan Approval

Submitted

By: Campbell Soup Company
E. Maumee Ave.
Napoleon, Ohio 43545

- Architect
- Engineer
- Other
- New
- Addition
- Alteration
- Mixed Occupancy
- Change of Occupancy

NAME AND LOCATION OF JOB

OWNER'S AGENT

<u>River Water Inlet and Pumping Station</u> <u>South Bank of River 160' upstream</u> <u>of D T&I Railroad Bridge</u>	<u>L. O. Smith</u> <u>Resident Engineer</u> <u>Campbell Soup Company</u>
---	--

TYPE OF CONSTRUCTION (Where Applicable) Type II - Non-Combustible Construction

O.B.C. Type of Occupancy 4101:2-69 **Stories** _____ **Basement** _____

Inspections shall be called for by the builder 48 hours in advance before work is covered. Final inspection must be made before building can be used or occupied. THIS CERTIFICATE SHALL REMAIN POSTED IN A CONSPICUOUS AND SAFE PLACE UNTIL COMPLETION OF JOB. APPROVED PLANS MUST BE KEPT ON JOB SITE AT ALL TIMES DURING CONSTRUCTION.

Plans, specifications and/or application as described above are hereby approved with addendum.

Date of Approval 4-6-77

BY: Norman Hoover
PLAN EXAMINER

This approval does not cover the water supply, plumbing and drainage. Plans and specifications for this class of work shall be submitted to the Division of Plumbing, State Department of Health for examination and approval. For approval of pressure piping, contact the Division of Pressure Piping, 2323 W. Fifth Ave., Columbus, Ohio. Zoning for Napoleon is not included in this approval.