

154 WEST MAUMEE AVENUE
ILLEGAL DOWNSPOUT INVESTIGATION

INSPECTED: MARK SPIESS

ILLEGAL DOWNSPOUT CONNECTION HAS BEEN
DISCONNECTED AND PIPE CAPPED TO REMAIN
A SANITARY CLEANOUT.

