

# CITY OF NAPOLEON GENERAL PERMIT APPLICATION

THIS APPLICATION IS FOR RESIDENTAL CONSTRUCTION INCLUDING BUILDING, ELECTRICAL,  
PLUMBING, MECHANICAL & REMODELING

KH 13-0304 / KH 13-0305  
Bldg - garage / Bldg - siding  
floors

DATE 8-6-13 JOB LOCATION 402 W MAUMEE

OWNER SCOTT LODG TELEPHONE # 419-966-7648

OWNER ADDRESS 402 W MAUMEE

CONTRACTOR TAYLOR CONSTRUCTION CELL PHONE # 419-769-1317

DESCRIPTION OF WORK TO BE PERFORMED FRAME IN & INSTALL 16' x 7' OVERHEAD

DOOR IN GARAGE AND 36' WALK IN DOOR. TEAR OFF SIDING & REPLACE WITH VINYL D4 DUTCH LAP

ESTIMATED COMPLETION DATE 8-30-13 ESTIMATED COST \$15,000.00

Affected Floor Area (AFA): In existing structures, it is the area affected by the improvement, i.e. a new wall dividing a room (the AFA would be only the room and not all the rooms).

DESCRIPTION	FEE	TOTAL COST
<b>BUILDING:</b>		
<i>Decks</i>	\$25.00	\$
<i>Addition &amp; Alterations</i> Square foot in (AFA) _____ x \$0.05 = \$ _____ +	\$25.00 =	\$ 25 <sup>00</sup>
<i>Garage and Shed over 200 SF (Detached)</i>	\$25.00	\$
<i>Siding and/or Roofing</i>	\$25.00	\$ 25 <sup>00</sup>
<i>Windows/Doors</i>	\$25.00	\$
<b>ELECTRICAL:</b>		
<i>Electrical</i> Circuits in (AFA) _____ x \$3.00/Circuit = \$ _____ +	\$25.00 =	\$
<i>Electrical Service Upgrade</i>	\$25.00	\$
<b>MECHANICAL:</b>		
<i>Water Heater</i>	\$25.00	\$
<i>Furnace and/or AC Replacement</i>	\$25.00	\$
<b>PLUMBING:</b>		
<i>Plumbing</i> Traps in (AFA) _____ x \$3.00/Trap = \$ _____ +	\$25.00 =	\$
<b>TOTAL plus Ohio Board of Building Standards Fee 1%</b>		<b>\$ 50</b>

**TOTAL FEE: \$ 50.50**

I FULLY UNDERSTAND THAT NO EXCAVATION, CONSTRUCTION OR STRUCTURAL ALTERATION, ELECTRICAL OR MECHANICAL INSTALLATION OR ALTERATION OF ANY BUILDING STRUCTURE, SIGN, OR PART THEREOF AND NO USE OF THE ABOVE SHALL BE UNDERTAKEN OR PERFORMED UNTIL THE PERMIT APPLIED FOR HEREIN HAS BEEN APPROVED AND ISSUED BY THE CITY OF NAPOLEON BUILDING/ZONING DEPARTMENT.

I hereby certify that I am the Owner of the named property, or that the proposed work is authorized by the Owner of record and that I have been authorized by the Owner to make this application as his/her authorized agent and I agree to conform to all applicable laws of the jurisdiction. In addition, if a permit for Work described in this application is issued, I certify that the code official or the code official's authorized representative shall have the authority to enter areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit.

I HEREBY ACKNOWLEDGE THAT I HAVE READ AND FULLY UNDERSTAND THE ABOVE LISTED INSTRUCTIONS.

SIGNATURE OF APPLICANT: [Signature] DATE: 8-6-13

PRINT NAME: CRAIG TAYLOR

PERMIT # \_\_\_\_\_ BATCH # \_\_\_\_\_ CHECK # 1285 DATE \_\_\_\_\_

**David L. Geringer P.E.**

---

Consulting Engineer

107 Ditto St., P.O. Box 99  
Archbold, Ohio 43502  
Phone (419) 446-2118

August 7, 2013

City of Napoleon  
255 W. Riverview  
Napoleon, Ohio 43545.  
Attn: Tom Zimmerman

Re: Scott Long Garage

Dear Mr. Zimmerman:

This letter is in regards to the overhead door header for the garage that is being constructed for Scott Long, Napoleon, Ohio. I have calculated the stresses on the header and have determined that 2 – 2 x 12's with ½" plywood between are adequate for the 16 ft. opening if the lumber is #1 S.Y.P. or better. The header is supporting only the roof and there will not be any storage above the garage ceiling.

If you have any questions please feel free to call me.

Sincerely,



David L. Geringer P.E.  
Consulting Engineer

