THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT 255 W. RIVERVIEW (419)592-4010

Plumbing Permit	Page 1 of 1
Permit Number: PL2009-36	Printed: 8/7/2009
ADDRESS: 408	Maumee Ave. W.
Applicant Name: Nathan Minnick Address: 71 Oak Dr	Approval Date: 7 /1/2009 419-592-4561
Owners	
Name: Mr. Nathan Minnick Address: 71 Oak Dr	Phone: 419-592-4561
Napoleon, OH 43545	
Contractors	
Contractor Type: Plumber Name: M & R Hancock & Son	Stryker, OH 43557
Address: 21216 State Route 34	Phone: 419-682-7249
Fees and Receipts:	
Number Description	on Amount
	Total Fees: \$0.00
	Total Receipts: \$0.00
Footer tile drain outlet to river.	
APPLICANTS SIGNATURE:	DATE:
REMINDER: YOU MUST	Γ CALL (419)592-4010 FOR AN INSPECTION

THE CITY OF NAPOLEON BUILDING & ZONING DEPARTMENT 255 W. RIVERVIEW (419)592-4010



Page 1 of 1

Printed: 8/7/2009

Inspections

Address: 408 Maumee Ave. W.

Napoleon, OH 43545

Applicant: Nathan Minnick

Permit Number: PL2009-36

Inspection Date:

8/7/2009

Inspector: Marty Crossland

Inspection Number:

INSP2009-104

Status: Complete

Inspection Type:

Plumbing Final

Passed? ✓

Required Steps:

Comments: Had to replace 10 ft. section of 18" vit. pipe with PVC while tapping 8".

Other Fields: