



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-4010

February 20, 1984

Mayor
Robert G. Heft

Clerk-Treasurer
Rupert W. Schweinhagen

Members of Council
Darel Austermilller, President
James Jackson
William Young
Lawrence Haase
Darrell Fox
James Zumfelde

City Manager
Richard A. Hayward

Law Director
Keith P. Muehlfeld

Mr. David Schlade
Co. Rd. 15
Napoleon, OH 43545

Dear Mr. Schlade:

The disconnect panel of the electric service on your house at 132 Meekison has become a hazard to the health of the residents of the house and community. Panel cover will not stay on and leaves fuse lugs and service lugs exposed to the public. Panel is not a waterproof box.

Service is 60 amp. Service shall be upgraded within 15 days, or by March 8th, or service shall be discontinued.

Your cooperation in this matter is appreciated.

Yours truly,

Richard G. Hayman
Building Commissioner

RGH:dd

*Panel cover fastened in place
march 22 1984
Ryck*