

**PERMIT**

**CITY OF NAPOLEON - BUILDING DEPARTMENT**

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01944 Issued 3-30-90 date

Job Location 910 Melody Lane address

Lot 11 Brickyard Subdivision sub-div or legal discript

Issued By Eldon Huber building official

Owner Mike Michaelis 592-0323 name tel.

Address 125 W. Washington

Agent Beck's Construction 592-8307 address tel.

Address 11-622 Rd. M builder-eng.-etc.

Description of Use Residence

Residential 1 no. dwelling units

Commercial Industrial

New  Add'n. Alter Remodel

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 49,500.00

**ZONING INFORMATION**

district	lot dimensions	area	front yd	side yds	rear yd
A	72' X 100'	7200 SF	30'	L-10' R-10'	23.67'
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr
35'	2-min		35%	None	

**WORK INFORMATION:**

Size: Length 42 Width 30 Stories 1 Garage Fl. area 484 cu. ft.  
Height 13' Building Volume (for demo. permit) \_\_\_\_\_

Electrical: 200 AMP Underground service & 16 new circuits brief description

Plumbing: 2 Bath, kitchen and laundry brief description

Mechanical: 75,000 BTU Natural Gas Fired Furnace & 7 hot air runs brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area **PAID**

Additional Information: New one story residence APR 10 1990

CITY OF NAPOLEON

Date 4-10-90 Applicant Signature Gregory J Beck owner-agent

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	9.00	128.00	137.00
<input checked="" type="checkbox"/> ELECTRICAL	15.00	48.00	225.00
<input checked="" type="checkbox"/> PLUMBING	9.00	30.00	39.00
<input checked="" type="checkbox"/> MECHANICAL	18.00		18.00
<input checked="" type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING	5.00		5.00
<input checked="" type="checkbox"/> SIGN			
<input type="checkbox"/> WATER TAP	375.00		375.00
SEW. INSP.			
SEWER TAP	60.00		60.00
TEMP. WATER	10.00		10.00
TEMP. ELECT.	5.00		5.00
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES			937.00
LESS MIN. FEES PAID			
BALANCE DUE			

# INSPECTION RECORD

UNDERGROUND				ROUGH-IN				FINAL			
Type	Date	By	Type	Date	By	Type	Date	Type	Date		
<b>PLUMBING</b>	Building Drains		Drainage, Waste & Vent Piping	4/26	FH	Indirect Waste		Drainage, Waste & Vent Piping	5/4		
	Water Piping							Backflow Prevention	5/4		
	Building Sewer		Water Piping	4/26	FH	Condensate Lines		Water Heater	6/15/24		
	Sewer Connection							FINAL APPROVAL			
<b>MECHANICAL</b>	Refrigerant Piping		Refrigerant Piping			Chimney(s)		Grease Exhaust System			
			Duct Furnace(s)			Fire Dampers		Air Cond. Unit(s)			
	Ducts/Plenums		Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)		Refrigeration Equipment			
			Duct Insulation			Pool Heater		Furnace(s)			
<b>ELECTRICAL</b>	Conduits & or Cable		Conduits/Cable			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.		FINAL APPROVAL			
	Grounding & or Bonding		Rough Wiring			<input type="checkbox"/> Range <input type="checkbox"/> Dryer		Temp Service Temp Lighting			
	Floor Ducts Raceways		Service Panel Switchboard			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors		Fixtures Lampholders			
	Service Conduit		Busways Ducts			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder		Signs			
<b>BUILDING</b>	Temporary Power Pole		Subpanels			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable		Electric Mtr. Clearance			
	Location, Set-backs, Esmt(s)		Exterior Wall Construction			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)		FINAL APPROVAL			
	Excavation					Roof Covering Roof Drainage	FH	Smoke Detector			
	Footings & Reinforcing					Exterior Lath		Demolition (sewer cap)			
<b>ADDITIONAL</b>	Floor Slab		Interior Wall Construction			<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard		Building or Structure	6/28/24		
	Foundation Walls		Columns & Supports			Fire Wall(s) Fireplace Chimney					
	Sub-soil Drain		Crawl Space <input checked="" type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input checked="" type="checkbox"/> Vent <input type="checkbox"/> Access	FH	FINAL APPROVAL BLDG. DEPT.	6/28/24		
	Piles		Floor System(s)			Special Insp Reports Rec'd	FH	Certificate of Occupancy Issued	6/28/24		
<b>INSPECTIONS, CORRECTIONS, ETC.</b>				<b>INSPECTIONS, CORRECTIONS, ETC.</b>				<b>INSPECTIONS, CORRECTIONS, ETC.</b>			
C.C. CHARTER (KIC 4058) 4/26 FH 18' SPAN 2x8's @ 16"o.c. 40' O.T.											

RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON  
255 West Riverview Ave.  
Napoleon, Ohio 43545  
419/592-4010

ADDENDUM TO Permit No. 01994-(1)  
Owner MIKE MICHAELS  
Contractor STEEL CONSTRUCTION  
Location 710 ARLINGDALE

Please note the items checked below and incorporate them into your plans as indicated:  PERMIT NOT YET ISSUED, CORRECT PLANS AND RE-SUBMIT.  PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL	
<input checked="" type="checkbox"/> Provide approved smoke detector(s) as req'd.	
<input checked="" type="checkbox"/> Provide 1/2" gypsum wallboard between dwelling and garage, on garage side.	
<input checked="" type="checkbox"/> Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)	
Submit fully dimensioned plot plan.	
Provide min. of 1-3'0" x 6'8" exit door.	
Provide min. 22" x 30" attic access opening.	
Provide min. 18" x 24" crawl space access opening.	
Provide approved sheathing or flashing behind masonry veneer.	
Provide min. 15# underlayment on roof.	
Provide adequate fireplace hearth.	
Install factory built fireplaces/stoves according to manufacturers instructions.	
Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.	
LIGHT AND VENTILATION	
Provide mechanical exhaust or window in bathroom	
Provide min. <u>837</u> Sq. In. net free area attic ventilation.	
Provide min. <u>121</u> Sq. In. net free area crawl space ventilation. <u>03' FR. N.A. CORN.</u>	
FOUNDATION	
Min. depth of foundation below finished grade is 32".	
Min. size of footer <u>        </u> " x <u>        </u> ".	
Provide anchor bolts 1/2" @ 6' o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.	
Show size of basement columns.	
FRAMING	
Show size of wood girder in <u>        </u> .	
Provide design data for structural member in <u>        </u> .	
Floor joists undersized in <u>        </u> .	
Provide double joists under parallel bearing partitions.	
Provide 1" x 4" let in corner bracing, approved sheathing, or equal.	
Show size of headers for openings over 4' wide <u>        </u> .	
	Show size of members supporting porch roof.
	Provide double top plate for all bearing partitions and exterior walls.
	Provide design data for prefab wood truss.
<input checked="" type="checkbox"/>	Ceiling joists undersized in <u>BEDROOM #1</u> .
	Roof rafters undersized in <u>        </u> .
	PLUMBING AND MECHANICAL
<input checked="" type="checkbox"/>	Terminate all exhaust systems to outside air.
<input checked="" type="checkbox"/>	Insulate ducts in unheated areas.
<input checked="" type="checkbox"/>	Provide backflow prevention device on all hose bibs.
<input checked="" type="checkbox"/>	Terminate pressure and temperature relief valve drain in an approved manner.
	Provide dishwasher drain with approved air gap device.
	METAL VENEERS
	Contact City Utilities Dept. to remove conductors and/or meter.
	Provide approved system of grounding and bonding.
	ELECTRICAL
<input checked="" type="checkbox"/>	Show location of service entrance panel and service equipment panel.
<input checked="" type="checkbox"/>	G. F. C. I. req'd. on temporary electric.
<input checked="" type="checkbox"/>	Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I. <u>KITCHEN</u>
<input checked="" type="checkbox"/>	Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.
<input checked="" type="checkbox"/>	Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.
	INSPECTIONS
	The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs. prior to the time the inspection is to be made.
<input checked="" type="checkbox"/>	Footers and Setbacks. <input checked="" type="checkbox"/> Building sewer.
<input checked="" type="checkbox"/>	Foundation. <input checked="" type="checkbox"/> HVAC rough-in.
<input checked="" type="checkbox"/>	Plumbing rough-in. <input checked="" type="checkbox"/> Final Building
<input checked="" type="checkbox"/>	Plumbing final. <input checked="" type="checkbox"/> other.
<input checked="" type="checkbox"/>	Electrical service. <input checked="" type="checkbox"/> <u>TOOLBOX FRAMING</u>
<input checked="" type="checkbox"/>	Electrical rough-in.
<input checked="" type="checkbox"/>	Electrical final

Additional Corrections. PROVIDOR 2 - 112" x 18" ANCHOR BOLTS FOR THE GIRDER  
7" EACH 16" x 16" BLOCK FORM PIER 1 PROVIDOR 2 x 8 CELL JOIST  
6" O.C. OVER BEDROOM #1 #2 SIPS OR BETTER

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01994 and made a part thereof. DATE APPROVED OR DISAPPROVED 1-10-90 Checked by E. COON HUBER  
Plan Examiner.



FIELD CORRECTION NOTICE

LOCATION 910 MELODY LAKE PERMIT NO. 0199A  
ISSUED TO BACK'S CONSTRUCTION  
NOTICE DELIVERED TO DECK'S CONSTRUCTION 11-622 Co Rd M

Upon inspection, violations of the C.A.I.D.O. Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction:  
INSTANT HEADLINE OVER OPENING ON THE  
EAST SIDE OF THE HALL WAY AS SHOWN  
ON PLANS. NOT REPAIR 2x8 ~~RE~~ CEILING.  
CONDS ARE INSTALLED

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED ON OR BEFORE REFOR INSTANTING DEYWAIC BY EIDON HUTER INSPECTOR  
DATE 4-26-90

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY





FIELD CORRECTION NOTICE

LOCATION 710 WELCOY C401 PERMIT NO. 01992  
ISSUED TO DEEY CONSTRUCTION  
NOTICE DELIVERED TO DEEY CONSTRUCTION 11-622 W RO 41

Upon inspection, violations of the C.A.D.O. Sec. \_\_\_\_\_ were in evidence.

The following orders are hereby issued for their correction:

REMOVE HANDRAIL OVER OPENING ON THE EAST SIDE OF THE HALL WAY AS SHOWN ON PLANS. 1 1/2" DIA. IS 2" DIA. 100 C.C. 1 1/2" DIA. 100 C.C.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE Before Inspecting Permitted

DATE 4-26-90 BY Eileen Hoover INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY





FIELD CORRECTION NOTICE

LOCATION 910 4 915 MELCOTT C AVE PERMIT NO. 01943 & 01944  
ISSUED TO BECK'S CONSTRUCTION  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.  
NOTICE DELIVERED TO BECK'S CONSTRUCTION 11-622 RD M

Upon inspection, violations of the C.A.M.D. Sec. 27A.04(2) were in evidence.  
SIX INFO

The following orders are hereby issued for their correction:

INSTALL 2 - 11/2" DIA x 18" ANCHOR BOLTS PER  
CRANE SPACK FOUNDATION PIER TO ATTACH THE  
FLOOR GIRDERS TO THE PIERS. BOLTS TO EXTEND  
15" INTO CONC. BLOCK PIERS.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE INSTALLING FLOOR DECK

DATE 4-9-90 BY ELDON HUBER INSPECTOR

PINK - ORIGINAL COPY WHITE - FIELD COPY YELLOW - FILE COPY



FIELD CORRECTION NOTICE

LOCATION 710 4915 MELBOURNE LANE PERMIT NO. 01743 Y 01902

ISSUED TO DECK CONSTRUCTION

NOTICE DELIVERED TO BLACK CONSTRUCTION 11-222 RD N

Upon inspection, violations of the Code Sec. 1070 were in evidence.

The following orders are hereby issued for their correction:

- 1052112 2 - 12" DIA x 18" ANCHOR (2001) PER
- CRANE (PARK FURNITURE) PIER TO BE REMOVED
- FLOOR BEING TO THE PIERS. (1017) TO EXTEND
- 10-11 1070 CONC. CLOCK PIERS.
- BY 7/11/90 SW
- BY 7/11/90

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 10/27/90 7/11/90 BY Arthur Egan INSPECTOR

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY



APPLICATION  
for

RESIDENTIAL BUILDING, ELECTRICAL, PLUMBING, MECHANICAL, PERMITS AND DEMOLITION PERMIT

from the

CITY OF NAPOLEON - BUILDING DEPARTMENT  
255 West Riverview Ave. Napoleon, Ohio 43545 Ph. 419-592-4010

Entry No. \_\_\_\_\_

Permit No. 01998 Issued 3-30-80

Chk. Permits Req. Base Fees Plus Total

Job Location 910 Melody Lane

128.00 137.00

Lot 11 Back Yard

225.00 40.00 265.00

Issued By EA sub-div. or legal disc.

65.00

Owner Mike Michaelis Ph 592 0323

70.00 79.00

Address 125 W Washington

18.00 18.00

Agent Beck's Const Co Ph 592 8307

5.00 51.00

Address 11622 Rd M Napoleon

375.00 375.00

Description of Use New Ranch RESIDENCE

60.00 60.00

Residential 1

10.00 10.00

Commercial 0

5.00 5.00

NEW ✓ Add'n. 1 Alter \_\_\_\_\_ Remodel \_\_\_\_\_

Additional struc. \_\_\_\_\_ hrs \_\_\_\_\_

Mixed Occupancy \_\_\_\_\_

Elect. \_\_\_\_\_ hrs \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Total Fees..... 937.00

Estimated Cost \$ 49,500

Less Min. Fees Pd. \_\_\_\_\_

Balance Due..... \_\_\_\_\_ date \_\_\_\_\_

**-ZONING INFORMATION**

district On Plot Plan

front yd \_\_\_\_\_ side yds. \_\_\_\_\_ rear yd \_\_\_\_\_

lot dimensions 72' x 100' area 7200 sq ft

max hgt 35' no pkg spaces \_\_\_\_\_ no lgg spaces \_\_\_\_\_ max cover 30% petition or appeal req'd. \_\_\_\_\_ date appr \_\_\_\_\_

2-MIN

NOND

**WORK INFORMATION:**

Garage Fl. Area 484 Stories 1 Ground Floor Area 1260 Second Floor Area 0

Size: Length 42 Width 30

Building Volume (for demo. permit) \_\_\_\_\_ cu. ft. \_\_\_\_\_

Height 8' 13"

Description of Work: New Ranch NEW 1-3004 RESIDENCE

Continue on Back Side for Electrical, Plumbing and Mechanical and other Information

ELECTRICAL: Electrical Contractor Bock's Cont Ph. 592 8307

Address 11622 Rd M Nap O Estimated Cost \$           

Type of work: New  Service change  Rewiring  Additional Wiring  Temp. Elec. Req.  X

Size of service 200 Undergound  Overhead  No. of new circuits 16 Yes  No

Description of work: ~~Wiring~~ 260 AMP UNDERGROUND SERVICE  
+ 16 CIRCUITS

PLUMBING: Plumbing Contractor Meyers Pumping + HT. Inc. Ph. 592 6771

Address 829 N. Perry Estimated Cost \$           

Water Tap Req.  YES  NO Size 3/4 Type of Pipe 4" Water Dist. Pipe 3/4 Plastic

San. Sewer Tap Req.  YES  NO Size 4" Type of Pipe 4" Plastic Dr. Waste Vt. Pipe 4" Plastic

St. Sewer Tap Req.  YES  NO Size 4" Type of Pipe Plastic Street to be Opened  X

Main Building Drain Size 4 Main Vent Pipe Size 4 List Number of Plumbing Fixtures Below

Water Closets 2 Bathtubs 1 Showers 1 Lavatories 2 Kitchen Sinks 1 Dishwasher 1 Clothes Washer 1

Floor Drains 0 Other Fixtures: Type            No.           

Description of Work: ~~Wiring~~ 2-DAY KITCHEN + LAUNDRES

MECHANICAL: Mechanical Contractor Meyers Pkg + HT. Ph. 592 6771

Address 829 N Perry Estimated Cost           

Heating System: Forced Air  Gravity  Hot Water  Steam  Unit Heaters  Radiant  Baseboard

Type of Fuel: Electric  Natural Gas  Propane  Wood  Coal  Solar  Geothermal  Other

No. of Heat Zones 1 Hot Water: (One Pipe  Two Pipe  Series Loop  ) Electric Heat: (No of Circuits  ) No. of Furnaces 1

No. of Hot Air Runs 7 No. of Hot Water Radiators 6500 Total Heat Loss 6500 Rated Capacity of Furnace/Boiler 75,000

Location of Heating Units: Crawl Space  Floor Level  Attic  Suspended  Roof  Outside  Other

Description of Work Wiring 75,000 B.T.U. FURN WAT GAS FIRED AIR RUNS X 7 HO7

**DRAWINGS REQUIRED:** All Applications must be accompanied by Two Complete sets of Drawings Including SITE PLAN, FOUNDATION PLAN, FLOOR PLANS, STRUCTURAL FRAMING PLANS, EXTERIOR ELEVATIONS, SECTIONS and DETAILS, STAIR DETAILS, ELECTRICAL LAYOUT, PLUMBING ISOMETRIC, HEATING LAYOUT ETC. ALL PLANS SHALL BE DRAWN TO SCALE. Show all existing structures on the site plan also, show Electric Panel and Furnace Locations.

**READ AND SIGN BELOW;** The undersigned hereby makes application for a permit for all work described herein, and agrees to complete the work in strict accordance with all applicable provisions of the current edition of the C.A.B.O. Building Code, the Napoleon Building and Zoning Codes, the Napoleon Engineering Dept. Rules and Regulations, Standard Specifications and other Pertinent Sections of the Napoleon Code of Ordinances.

Date 3/30/90 Signature of Applicant Robert Bock Application not valid without signature



FIELD CORRECTION NOTICE

LOCATION 910 MELODY LAVE PERMIT NO. 01944  
ISSUED TO DECK'S CONSTRUCTION  
NOTICE DELIVERED TO DECK'S CONSTRUCTION 11-622 CORDM

Upon inspection, violations of the C.A.B.D. Sec. R-602.7 were in evidence.

The following orders are hereby issued for their correction:

YOU ARE HEREDY DIRECTED TO STOP WORK  
ON THIS PROJECT UNTIL YOU COMPLY WITH  
THE ANCHOR BOLT REQUIREMENT LISTED ON  
YOUR PLAN CORRECTION SHEET AND THE FIELD  
CORRECTION NOTICE ISSUED 4-9-90

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE BEFORE CONTINUING WORK BY ELOAN KUDER INSPECTOR  
DATE 4-16-90

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY





FIELD CORRECTION NOTICE

LOCATION 910 AILEYDRI LAVE PERMIT NO. 01944

ISSUED TO SECK'S CONSTRUCTION  
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO SECK'S CONSTRUCTION 11-622 CO. ROAD

Upon inspection, violations of the C.A.T.D. Sec. R-602.7 were in evidence.

The following orders are hereby issued for their correction:  
YOU SEE HERBY DIRECTED TO (TOP WORK)  
ON THIS PROJECT WITH YOU COMPANY WITH  
THE ANCHOR BELT REQUIREMENT LISTED ON  
YOUR PLAN CORRECTION MUST AND THE FIELD  
CORRECTION NOTICE ISSUED 4-9-90

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED, ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE before construction work BY Eileen Huber INSPECTOR  
DATE 4-16-90

PINK - ORIGINAL COPY    WHITE - FIELD COPY    YELLOW - FILE COPY

