

1150 MICHIGAN AVENUE

2015

N
1"=20'

~~MICHIGAN AVENUE~~
LAGRANGE STREET

Investigation of illegal sewer connections revealed four (4) illegal connections. All downspouts have been corrected and are in compliance at this time.

12" Stm.

Michigan Ave.

6" W.M. (Transite)

1150

SUMP PIT
4" c/b
CAPPED & SEALED BELOW GRADE

CAPPED & SEALED BELOW GRADE

CAPPED, GWED & SCREWED ON AT GRADE (IN WALK)

SCANNED