

PERMIT

**CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010**

335

Permit No. _____ Date Aug. 19, 1981
 Job Location 522 Monroe Valuation \$ 6,950
 Owner Imogene Fredrick Address 522 Monroe
 Contractor George Taylor Telephone No. 784-0327
 Address Rt. 2, Lake Christy Meadows, Defiance, Ohio
 Electric Contractor _____
 Plumbing Contractor _____
 Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential No. Dwelling Units _____ Commercial _____ Industrial _____
 New Construction Addition _____ Remodel _____ X
 Brief Description of Work Remodeling for CDBG program

ISSUED BY Richard G. Ferguson Building Official DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit \$ 19.50
 Electrical Permit \$ 9.00
 Plumbing Permit _____
 Mechanical Permit _____
 Demolition Permit _____
 Zoning Permit _____
 Sign Permit _____
 Water Tap _____
 Sewer Tap _____
 Temp. Elec. _____
 Other _____

TOTAL FEES \$ 28.50
 LESS FEES PAID \$ -0-
 BALANCE DUE \$ 28.50

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

AUG 19 1981

CITY OF NAPOLEON
 BUILDING INSPECTION DEPARTMENT
 APPLICATION FOR BUILDING PERMIT
 (Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 522 MONROE ST Cost of project \$6,950

Owner's Name MOGENE FREDRICK Address 522 MONROE ST.

Contractor GEORGE TAYLOR Telephone No. 784-0327

Address RT #2, LAKE CHRISTY MEADOWS, DEFIANCE, OHIO

Lot Information: (Not required for siding job)

Lot No. 37 Subdivision ORIGINAL PLAT

Zoning District GB Lot Size ft. X ft. Area sq. ft.

Setbacks: Front ft. Right Side ft. Left Side ft. Rear ft.

Work Information:

Residential IX Commercial Industrial

New Construction Addition Remodel X

Accessory Building Siding Unyl or Aluminum
 (Specific Type)

Brief Description of Work: ----- REMODELING FOR CDB6 RE-HAB PROGRAM

Size: Length Width No. of Stories

Area: 1st Floor sq. ft. Basement sq. ft.

2nd Floor sq. ft. Accessory Bldg. sq. ft.

3rd Floor sq. ft. Other sq. ft.

Additional Information:

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date Applicant's Signature

PERMIT NO. 335

PERMIT FEE \$ 19.50

CITY OF NAPOLIFON
 BUILDING INSPECTION DEPARTMENT
 APPLICATION FOR ELECTRICAL PERMIT
 (please print or type)

The undersigned hereby makes application for installation and replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name IMOGENE FREDRICK Address 522 MONROE ST.

Electrical Contractor GUSTWILLER ELECTRIC Telephone No. 395-2201

Address RT #7, DEFIANCE, OHIO

General Contractor GEORGE TAYLOR Telephone No. 784-0327

Address RT #2, LAKE CHURCH MEADOWS, DEFIANCE, OHIO

Location of Project 522 MONROE ST Cost of Project \$6,950.00

Work Information:

Residential 1 Commercial Industrial

New Service Entrance Rewiring Additional Wiring

Brief Description of Work: RE-WIRING OF HOUSE FOR CDBG RE-HAB PROGRAM

Size of proposed service entrance _____ Number of new circuits 4

Type of proposed service entrance _____ Underground _____ Overhead

Require Temporary Electric NO (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information:

*GROUND FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 AMP AND 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE; AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. AWI, 210-8 N.E.C.

*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date _____ Applicant's Signature _____

335

9.00

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING 255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. _____ Date Aug. 19, 1981
Job Location 522 Monroe Valuation \$ 6,950
Owner Imogene Fredrick Address 522 Monroe
Contractor George Taylor Telephone No. 784-0327
Address Rt. 2, Lake Christy Meadows, Defiance, Ohio
Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:
Residential No. dwelling units _____ Commercial _____ Industrial _____
New Construction _____ Addition _____ Remodel _____
Brief Description of Work Remodeling for CDBG program

ISSUED BY _____ Building Official _____ DEPT. OF BUILDING & ZONING

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- _____ Footing excavation prior to placing concrete.
- _____ Footing drains and foundation prior to backfill.
- _____ Prepared sub-grade prior to placing concrete floor slab.
- _____ Sanitary sewer
- _____ Rough-in electrical, plumbing and service framing prior to installing wall board.
- _____ Final electrical, plumbing and heating.
- _____ Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ <u>19.50</u>
Electrical Permit	\$ <u>9.00</u>
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____

TOTAL FEES \$ 28.50
LESS FEES PAID \$ 19.00
BALANCE DUE \$ 9.50

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

INSPECTION RECORD

UNDERGROUND		ROUGH-IN & FINAL	
Type	Date	Type	Date
Sewer Connection		Drainage, W. & Vent.	
Building Sewer		Water Piping	
Water Piping		Condensate Lines	
		Indirect Waste	
		FINAL APPROVAL	
Floor Ducts		Rough Wiring	9-26 JAC
Raceways		Conduits/ Cable	
Conduits & or Cable		Service Panel	
Grounding & or Bonding	9-26 JAC	Switchboard	
		Subpanels	
		□ Range	
		□ Dryer	
Refrigerant Piping		Refrigerant Piping	
Ducts/ Plenums		Ducts/ Plenums	
		Ventilation	
		□ Supply	
		□ Exhst.	
Location, Set-backs, Esmt(s)		Wall Construction	
Excavation		Crawl Space	
		□ Vent	
		□ Access	
		Attic	
		□ Vent	
		□ Access	
Footings & Reinforcing		Floor System(s)	
Sub-soil Drain		Roof System	
Foundation		Fire Wall(s)	
Walls		Roof Cover	
Floor Slab		Roof Drain	
		Building or Structure	

BLDG. DEPT. — Certificate of Occupancy Issued #

10-7-81

Respon
Electrical
8-21, 24, 25, 26
August 8-28
Siding & Insulation
begun on 9-1-81



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-0010

January 10, 1983

Mr. Richard R. Radel
514 Monroe St.
Napoleon, OH 43545

Mayor
Robert G. Hett

Clerk-Treasurer
Rupert W. Schweinhagen

Members of Council
Darel Austermler, President

James Jackson
William Young
Lawrence Haase
Darrell Fox
James Zumfelde

City Manager
Richard A. Hayward

Law Director
Keith P. Muehlfeld

Dear Mr. Radel:

About one month ago, Gary Botticher and I dye-tested your sanitary sewer line and found it dumped into the storm line going into the river. This is prohibited under the City Ordinances and the sanitary line from your house shall be disconnected from the storm and tied into the sanitary sewer of the City.

The separation of the sanitary from the storm shall be completed within 30 days of this notice.

Your cooperation in this matter is appreciated.

Yours truly,

Richard G. Hayman
Building Commissioner

RGH:dd

TO RICHARD HAYMAN
DATE 04 APR 83 TIME 11:30AM

WHILE YOU WERE OUT

M IMOGENE FREDERICK
OF 522 MONROE

PHONE
AREA CODE NUMBER EXTENSION

TELEPHONED	PLEASE CALL	
CALLED TO SEE YOU	WILL CALL AGAIN	
WANTS TO SEE YOU	URGENT	
RETURNED YOUR CALL		

MESSAGE ~~518~~ MONROE SANITARY
IS EMPTYING INTO STORM
ON EAST MAIN --- 522 MONROE
SANITARY WILL NOT DRAIN

OPERATOR _____

