

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 805-77 Issued 8-22-77 date

Job Location 850 Monroe address

Lot _____ sub-div or legal discript

Issued By Ronald D. Sonnenberg building official

Owner Eldon Gottschalk name tel. _____

Address Tecumseh, Mich.

Agent Bob Butterfield builder-eng.-etc. tel. 592-6272

Address 720 Romain

Description of Use Install new service entrance.

Residential XX(1) no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. _____ Alter _____ Remodel XX

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 200.00

FEES	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	\$3.00	-0-	\$3.00
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
	Elect. _____ hrs		
TOTAL FEES.....			\$3.00
LESS MIN. FEES PAID _____ date			-0-
BALANCE DUE.....			\$3.00

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: Install new 150 amp. service entrance.
brief description

Plumbing: n/a
brief description

Mechanical: n/a
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: All work shall conform to the 1975 edition of the N.E.C.

Date 9-30-77 Applicant Signature Bob Butterfield
owner-agent

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/ Plenums			Ducts/ Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/ Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
				Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued		
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.					
	<i>violations -</i>						<i>10/13/77</i>					

Date: August 22-1977

TO: The Building Inspector - Engineering Dept.

FROM: Electric Distribution Superintendent

Confirmed the installation of 150 AMP. electrical

Plan

service entrance, located _____

880 Marwe

at the following address: _____
Not Approved _____

Approved _____ Date _____

W. Lang

electric supt.

Remarks: _____

CITY OF NAPOLEON
 BUILDING INSPECTION DEPARTMENT
 APPLICATION FOR ELECTRICAL PERMIT
 (PLEASE PRINT OR TYPE)

#3.00

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name ELDON GOTTSCHALK Address 850 MONROE

Contractor's Name BOB BUTTERFIELD Address 720 ROMAIN Tel. 592-6272

JOB INFORMATION:

Location of Project 850 MONROE zoning District _____

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____

New Construction _____ Existing _____ Addition _____

Replacement _____ Remodel _____ Service Change

Size: Total Square Feet Per Floor _____ No. of Stories _____

DESCRIPTION OF WORK:

Size of Service 150 AMP Service Changes Only (Yes or No)

Total Number of New Circuits _____ Total Number of New Circuits Exceeding Appliance Circuits _____

APPLIANCE CIRCUITS: (Indicate quantity)

Electric Range _____ Range Hood _____ Clothes Dryer _____ Dishwasher _____

Air Conditioner _____ Attic Fan Blower _____ Roof Exhaust Fan _____

Disposal _____ Hot Water Heater _____ Electric Oven _____

Require Temporary Electric _____ (Yes or No)

Note: G.F.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMITS SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISES PERMITS

ESTIMATED COST OF COMPLETED PROJECT: \$200.00

DATE _____ APPLICANT'S SIGNATURE _____

OWNER-CONTRACTOR-AGENT

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 10-13-77

Permit No. 805-77

Type of Inspection Electrical

Type of Occupancy One Family

Project Name Single Family (Collectible)

Address 250 Municipal

City Nap. State O.

Approved

Violation

Electrical Contractor

Remarks:	Code Reference
1- Service Conductors, decrease from ground (each) 10' min	230-24 b.
2- Grounding Conductors from grid rod City ord. to meter/central base, continuous, no splices or connections other than final terminations.	7
3- Provide vapor seal where roadway is exposed to different temperatures	300-7
4- NM Cable to be used in dry locations NMC may be used in damp locations	336-3 (a & b)
5. Supports for SE Cable	336-5

Compliance Time at once

Inspectors Signature M. Haves

Copies To:

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Date 10-13-77

Permit No. 805-77

Type of Inspection Electrical

Type of Occupancy One Family

Project Name Single Family (Bellechick)

Address 850 Mansel

City Nap. State O.

Approved

Violation

Electrical Contractor

Remarks:

Code Reference

1- Service Conductors, clearances from ground (earth) 10' min 332-24 b

2- Grounding Conductors, from end rod to meter neutral bar, continuous, no splices, no connections other than final terminations City Ord 7

3- Provide weep seal where penetration is exposed to different temperatures 309-7

4- PVC cable to be used in dry locations NVC may be used in damp locations 336-3 (a & b)

5. Supports for SE Cable 336-5

Compliance Time at once

Inspectors Signature M. Howes

Copies To:

