



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE, P.O. BOX 151
NAPOLEON, OHIO 43545-0151
(419) 592-4010

September 22, 1995

Mayor
Robert G. Heft

Members of Council
John E. Church, President
Michael J. DeWit
James Hershberger
Sarah Peper
Terri A. Williams
Travis B. Sheaffer
Dennis Filgor

City Manager
Marc S. Gerken

Finance Director
Gregory J. Heath

Law Director
David M. Grahn

Mr. Brent Gerken
Gerken Paving, Inc.
9-072 U.S. Rt. 24
Napoleon, Ohio 43545

Re: 16" Butterfly Valve Manhole

Dear Mr. Gerken:

This letter is in reference to the five (5) foot diameter valve manhole located approximately three (3) feet west of the foundation of your newly constructed house at 582 Moorings Drive. As the casting must be raised to meet the proposed grade, the City of Napoleon recommends the use of a transition slab and pre-cast cone section. Due to the location of the existing manhole steps and the depth of proposed fill, the use of adjusting rings to raise the casting is unacceptable. The above modifications shall be at your expense.

If you have any questions, please call me.

Yours truly,

Adam C. Hoff, P.E.
City Engineer

ACH:rd