

# METER YOKE RELEASE

This document is for the release of **one (1)** Water Meter Yoke for Residential water service lines.

RELEASE NO. 200

PERMIT NO. 3844 ISSUED 5-6-76

JOB LOCATION 582 Moorings

- Inside City Limits       - Outside City Limits

ISSUED BY BND

OWNER Brent Berken

ADDRESS 582 Moorings

CONTRACTOR Elling P/H

ADDRESS T-487 St. Rt. 108 Map

CONTRACTOR'S PHONE NO. 598-8991

WATER TAP SIZE:  = 1"       = 1-1/2"       = 2"

WATER METER s# \_\_\_\_\_

- New Dwelling       - Existing Dwelling

- Lawn Meter 1" horn

Water Service Line to be Type (K) Copper or (CTS) Polyethelene Tubing of one inch (1") minimum.

~~Watts No. 7 Dual check required~~  = Yes       = No

Pressure Vacuum breaker by Winter Lawn  
Water Meter Yoke installation is subject to the following conditions:

337-8392

- 1.) Must be located in an accessible area.
- 2.) Must be in an area not subject to freezing temperatures.
- 3.) Must be eighteen inches (18") above floor level, not in crawl spaces.
- 4.) Must comply with the mounting criteria and clearances as set forth in **DRAWING #04403901.**