

THE CITY OF NAPOLEON

BUILDING & ZONING DEPARTMENT

255 W. RIVERVIEW

(419)592-4010

Plumbing Permit

Permit Number: PL2009-3

Page 1 of 1

Printed: 1/28/2009

ADDRESS:

150 Northcrest Circle

Applicant

Name: Jon Bisher

Address: 150 Northcrest Circle

Approval Date: 1/28/2009

Owners

Name: Mr. Jon Bisher

Address: 150 Northcrest Circle

Napoleon, OH 43545

Contractors

Fees and Receipts:

| Number | Description | Amount |
|-----------------|------------------|-----------------|
| FEE2009-123 | Water 5/8" meter | \$350.00 |
| Total Fees: | | <u>\$350.00</u> |
| RCPT2009-115 | | \$350.00 |
| Total Receipts: | | <u>\$350.00</u> |

5/8 Lawn Meter

APPLICANTS SIGNATURE: _____ DATE: _____

REMINDER: YOU MUST CALL (419)592-4010 FOR AN INSPECTION

SCANNED



CITY OF NAPOLEON



BUILDING & ZONING DEPARTMENT
255 West Riverview Avenue, P. O. Box 151 Napoleon, OH 43545
Telephone: 419/592-4010 Fax: 419/599-8393
www.napoleonohio.com

WATER METER YOKE RELEASE FORM

THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" WATER METER YOKE ASSEMBLY
(Please pickup at City Operations Department 1775 Industrial Drive.)

Permit Number: pl 2009-01
Date Issued: 1/20/2009

Job Location 150 Northcrest Circle

Owner: Jon Bisher
Address: 150 Northcrest Circle

Phone: 419-592-1789

Contractor: Moore's Plumbing
Phone: 419-599-1993

Water Tap Size: 1" 1 1/2" 2" Other: _____
Water Meter Yoke Size: 5/8" 3/4" 1" Other _____
New Structure: Existing Structure: Lawn Meter:

WATER SERVICE LINE TO BE TYPE "K" COPPER OR "CTS" POLYETHELENE TUBING OF 1" MINIMUM SIZE.

Backflow Device Required? Yes No
Type of Backflow Required: *Double Check*

Water Meter Yoke Installation is subject to the following conditions:

1. Must be located in an accessible area.
2. Must be in an area which is not subject to freezing temperatures.
3. Must be at least 18" above floor level (no crawl space installations.)
4. Must comply with minimum mounting requirements (drawings available).

Issued By: *Tom Zimmerman*

Received By: *Jon A. Bisher*

1 Copy to: Building Dept, Water Dept.

COPY
T2