

DATE PAID

PAID

CITY OF NAPOLEON

NOV 2 1982

ELECTRICAL PERMIT APPLICATION

CITY OF NAPOLEON

PROJECT LOCATION 265 NORTHCREST
 OWNER JACK SCHROEDER CONTRACTOR COCHRAN ELECTRIC
 ADDRESS 265 NORTHCREST ADDRESS 525 N PERRY
 PHONE 599-0393 PHONE 592 0891
 LOT NO. _____ ADDITION _____

SERVICE INFORMATION

RESIDENTIAL
 COMMERCIAL _____
 INDUSTRIAL _____

NEW _____
 CHANGE _____

SERVICE SIZE 100AMP

OVERHEAD
 UNDERGROUND _____

MAIN DIS. EXT. _____
 INT. _____

TEMP. ELECT. NO
 (yes or no)

PANEL INFORMATION MINIMUM

#12 AWG Wire for receptical circuits.
 #14 AWG Wire for light circuits.
 All circuits shall be listed on the fuse or breaker or on the inside of panel door.

PERMIT FEES

RESIDENTIAL

BASE FEE \$5.00
 PLUS \$1.00 PER CIRCUIT _____
 TEMP. ELECT. \$10.00 _____

COMMERCIAL

PLANS W/SEAL PER STRUC. \$12.00
 PLUS \$.40 PER 100 SQ.FT. _____

PLANS, NO SEAL \$35.00 PER HOUR
 PLUS \$.55 per 100 SQ.FT.

IN THE ABSENCE OF A DETAILED BLUE PRINT DRAWING, PLEASE MAKE AN ISOMETRICAL DRAWING OF THE PROPOSED WORK. (TWO COMPLETE SETS)

LIGHTS AND APPLIANCES SHALL BE ON SEPERATE CIRCUITS. LIMIT EACH CIRCUIT TO NOT MORE THAN 1200 WATTS.

GROUND FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120 VOLT SINGLE PHASE, 15 AND 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE: AND ALSO ON BATHROOM, OUTDOOR AND GARAGE RECEPTICALS IN ALL DWELLING UNITS.

GROUNDING

RESIDENTIAL SERVICE GROUNDING SHALL CONSIST OF TWO SEPERATE PATHS TO GROUND. 1. A DRIVEN GROUND ROD. 2. TO THE SERVICE SIDE OF THE WATER SERVICE. MINIMUM GROUNDING WIRE SIZE SHALL BE #6 AWG.

METER SOCKET

METER SOCKETS WILL BE ISSUED BY THE CITY OF NAPOLEON ELECTRIC DEPT. AT NO CHARGE ONLY WITH A METER RELEASE SLIP FROM THE BUILDING DEPT.

INSPECTIONS REQUIRED: ROUGH IN AND FINAL.

DATE 11-2-82

CONTRACTOR SIGNATURE

[Handwritten Signature]

PERMIT NO. 532
PERMIT FEE \$ 5.00