

# APPLICATION FOR PERMIT TO TAP SEWER

(Print or Type)

Owner Murel E. Naveau NO. 725  
Address 1475 Oakdale Drive BLDG. PERMIT -----  
Contractor Shultz & Sons, Inc. PERMIT FEE \$ 0 FEE  
Address Read "R" Napoleon, Ohio 43545 Tel. 592-3946 DATE PAID -----

for office use only

## LOCATION OF CONNECTION

Street and No. 1475 Oakdale Drive Sanitary X Storm -----  
Lot No. 21 Subdivision Beckelmann 3rd addition Size of Tap 6"  
Size and Type of Sewer 6" vit. clay premium joint ALL WORK MUST BE INSPECTED

I certify that the sewer will be used only as indicated and no other Drainage will be connected.

Date ----- Signature ----- owner-builder-agent  
----- do not write below this line -----

## INSPECTION RECORD

Date Inspected October 8, 1976 Size and Type of Sewer 6" vit. clay prem. joint  
Location Rear of House Depth 4' @ Manhole Type of Test 10' head water  
Inspected and Approved By: Ronald D. Sauerberg October 8, 1976  
Inspector Date  
Additional Information No fees charged, this was a replacement of an existing sewer only.

Send copy to: Murel Naveau

## SKETCH OF INSTALLATION

