

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01614 Issued 8-31-88 date

Job Location 1106 Oakwood address

Lot 8 J. Brennans Add. sub-div or legal discript

Issued By Eldon Huber building official

Owner Michael Fry 592-6900 tel.

Address 1106 Oakwood

Agent Bergstedt Builders 592-3451 builder-eng.-etc.

Address 1050 Dodd Street

Description of Use Residence

Residential 1 no. dwelling units

Commercial Industrial Remodel

New Add'n. X Alter Remodel

Mixed Occupancy

Change of Occupancy

Estimated Cost \$ 22,000.00

ZONING INFORMATION

district	lot dimensions	area
C	63' x 165.74'	
max hgt	no pkg spaces	no ldg spaces
13'	2 - min.	5

WORK INFORMATION:

Size: Length 32'6" Width 12' Stories 1 Ground Floor Area 438 s.f.
 Height 13'± Building Volume (for demo. permit) _____ cu. ft.

Electrical: Relocate service entrance and upgrade to a 200 amp service.

Plumbing: 2 - bathrooms brief description

Mechanical: 3 hot air runs from the existing furnace. brief description

Sign: N.A. Dimensions Sign Area type

Additional Information: Dining Room, mud room and bedroom and with 2 bathrooms.

Date 9-2-88 Applicant Signature Michael J Fry owner-agent

<input checked="" type="checkbox"/>	BUILDING	9.00	62.00	71.00
<input checked="" type="checkbox"/>	ELECTRICAL	15.00	21.00	36.00
<input checked="" type="checkbox"/>	PLUMBING	9.00	18.00	27.00
<input checked="" type="checkbox"/>	MECHANICAL	18.00		18.00
<input type="checkbox"/>	DEMOLITION			
<input type="checkbox"/>	ZONING			
<input type="checkbox"/>	SIGN			
	WATER TAP			
	SEWER TAP			
	TEMP. ELECT.			
	ADDITIONAL PLAN REVIEW	Struct. _____ hrs		
		Elect. _____ hrs		
	TOTAL FEES			152.00
	LESS MIN. FEES PAID			
	BALANCE DUE			

PAID
SEP 02 1988

INSPECTION RECORD

UNDERGROUND			ROUGH-IN				FINAL	
Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains		Drainage, Waste & Vent Piping			Indirect Waste		
	Water Piping					Condensate Lines		
	Building Sewer		Water Piping					
	Sewer Connection							
MECHANICAL	Refrigerant Piping		Refrigerant Piping			Chimney(s)		
			Duct Furnace(s)			Fire Dampers		
	Ducts/Plenums		Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)		
			Duct Insulation			Pool Heater		
ELECTRICAL			Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.		
	Conduits & or Cable		Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer		
	Grounding & or Bonding		Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors		
	Floor Ducts Raceways		Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder		
	Service Conduit		Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable		
	Temporary Power Pole		Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)		
			Exterior Wall Construction			Roof Covering Roof Drainage		
						Exterior Lath		
						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard		
						Fire Wall(s) Fireplace Chimney		
BUILDING			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input checked="" type="checkbox"/> Vent <input checked="" type="checkbox"/> Access		
			Floor System(s)					
			Roof System			Special Insp Reports Rec'd		
ADDITIONAL	INSPECTIONS, CORRECTIONS, ETC.			INSPECTIONS, CORRECTIONS, ETC.				
	CHECK ADD SUPPORT FOR CEILING JOISTS			F4				
	PARTIAL LVY INSTALLED			11/7 F4				

ADDITIONAL

INSPECTIONS, CORRECTIONS, ETC.

CHECK ADD SUPPORT FOR CEILING JOISTS

PARTIAL LVY INSTALLED

F4

11/7 F4

INSPECTIONS, CORRECTIONS, ETC.

FINAL APPROVAL BLDG. DEPT.

Certificate of Occupancy Issued

F4

F4

F4

F4

F4

BUILDING

ELECTRICAL

MECHANICAL

PLUMBING

FINAL

ROUGH-IN

UNDERGROUND

Date By

Type

Date

By

Type

Date

By

Type

Date

By

Type

Date

By

M
H

Drainage, Waste & Vent Piping

Indirect Waste

Drainage, Waste & Vent Piping

Water Piping

Backflow Prevention

Condensate Lines

Water Piping

Water Heater

FINAL APPROVAL

Grease Exhaust System

Chimney(s)

Refrigerant Piping

Air Cond. Unit(s)

Fire Dampers

Duct Furnace(s)

Refrigeration Equipment

Radiant Htr(s)
 Unit Htr(s)

Ducts/Plenums

Furnace(s)

Pool Heater

Duct Insulation

FINAL APPROVAL

Ventilation
 Supply Exhst.

Combustion Products Vents

Temp Service Temp Lighting

Range
 Dryer

Conduits/Cable

Fixtures Lampholders

Generator(s)
 Motors

Rough Wiring

Signs

Water Htr
 Welder

Service Panel Switchboard

Electric Mtr. Clearance

Heaters
 Heat Cable

Busways Ducts

FINAL APPROVAL

Duct Htr(s)
 Furnace(s)

Subpanels

Smoke Detector

Roof Covering
Roof Drainage

Exterior Wall Construction

Demolition (sewer cap)

Exterior Lath

Building or Structure

Interior Lath
 Wallboard

Interior Wall Construction

Fire Wall(s)
Fireplace
Chimney

Columns & Supports

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

01614
 8

Permit No. Issued 8-31-88 date
 Job Location 1106 OAKWOOD address
 Lot 8 N. BREANONS AOD sub-div or legal descripi
 Issued By 54 building official
 Owner MICHAEL FRY 592-6200 tel
 Address 1106 OAKWOOD
 Agent BERNARD BOLDRS 592-3457
 Address 1050 000057 builder-eng-etc tel
 Description of Use RESIDENCY

	FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING		7.00	62.00	71.00
<input checked="" type="checkbox"/> ELECTRICAL		15.00	21.00	36.00
<input checked="" type="checkbox"/> PLUMBING		9.00	18.00	27.00
<input checked="" type="checkbox"/> MECHANICAL		18.00		18.00
<input type="checkbox"/> DEMOLITION				
<input type="checkbox"/> ZONING				
<input type="checkbox"/> SIGN				
<input type="checkbox"/> WATER TAP				
<input type="checkbox"/> SEWER TAP				
<input type="checkbox"/> TEMP. ELECT.				
ADDITIONAL PLAN REVIEW	Struct.		hrs	
	Elect.		hrs	
TOTAL FEES.....				152.00
LESS MIN. FEES PAID				
BALANCE DUE.....				

Residential 1 no dwelling units
 Commercial Industrial
 New Add'n. X Alter Remodel
 Mixed Occupancy
 Change of Occupancy
 Estimated Cost \$ 16,800.00
6000.00 GEORGAS
2500.00 PLUMB,
1500.00 EL,
1200.00 HEATING
22,000.00 TOTAL

ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
C	63' X 165.74'		17'±	18.75±	19.75±
max hgt	no pkg spaces	no lgd spaces	max cover	petition or appeal req'd	date appr
13'	2-MIX		95%		

WORK INFORMATION:

Size: Length 32'-6" Width 12'-0" Stories 1 Ground Floor Area 438 S.F.
 Height 13'± Building Volume (for demo. permit) cu. ft.
 Electrical: RELOCATE SERVICE ENTRANCE TO GRADN TO A 200 AMP SERVO,
 Plumbing: 2- BATHROOMS
 Mechanical: 3 HOT AIR PUM FROM THE EXISTING FORNACE

Sign: 4 A.1 Dimensions Sign Area
 Additional Information: DINING ROOM, MUD ROOM & BEDROOM AOD WITH 2- BATHROOMS

Date Applicant Signature Owner-agent
 White-Building Department Yellow-Applicant Pink-Electrical Inspector Green-Client-Treasurer Gold-County Auditor 98

CITY OF NAPOLEON

BUILDING INSPECTION DEPARTMENT
APPLICATION FOR PLUMBING PERMIT

2500

(Please print or type)

The undersigned hereby makes application for the installation or replacement of plumbing work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Plumbing Codes. (1, 2 and 3 family dwelling units only).

Owner's Name Michael Fry Address 1106 Oakwood
 Plumbing Contractor Bugsford Bldg Telephone No. 592-~~51~~ 6900
 Address 1050 Oak St Nap Oh
 General Contractor Bugsford Bldg Telephone No. 592-3451
 Address 1050 Oak St Nap Ohio
 Location of Project 1106 Oakwood Cost of Project 2500.00

Work Information:
 No. of dwelling units 1 New 1 Replacement Addition 1
 Permit No.
 Permit Fee \$ 27.00
 Brief description of work: Bathroom Drain & water

Is water tap required X Size 1" Type of Pipe Copper
 Is sewer tap required MU Size Type of Pipe

Type of Water Distribution pipe Copper to house plastic in home
 Type of Drainage, Waste and Vent Pipe Plastic
 Size of main building drain 4 Size of main vent pipe 3"

Water closets 2 Bathtubs 1 Shower Trap Size
 No. Trap Size No. Trap Size

Lavatories 2 Kitchen Sink Disposal yes Trap Size
 No. Trap Size No. Trap Size

Dishwashers MU Clothes Washer yes Other Trap Size
 No. Trap Size No. Trap Size

All installed items are subject to plumbing tests and/or inspections.

Date 8-29-88 Applicant's Signature Michael Fry

6 TRAPS 18.00
 9.00

01831
525
32

BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

1500.00^{or}

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Michael Fry Address 1106 Oakwood

Electrical Contractor Beghtel Bldg Telephone No. 592-3451

Address 1050 Dodd St. Napoleon, Oh

General Contractor Beghtel Bldg Telephone No. 592-3451

Address 1050 Dodd St. Napoleon, Oh

Location of Project 1106 Oakwood Cost of Project 1500.⁰⁰

Work Information:

Residential 1 No. Units Commercial Industrial

New Service Change Rewiring Additional Wiring

Brief Description of Work: _____

Size of proposed service entrance _____ Number of new circuits 7

Type of proposed service entrance _____ Underground _____ Overhead _____

Require Temporary Electric _____ (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: RELOCATE EXISTING SERVICE (100 AMP)

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

Applicator for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

date 8-29-88 Applicant's Signature Michael Fry

PERMIT NO. _____

15.00
21.00
36.00

PERMIT FEE \$ _____

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR BUILDING PERMIT
(Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 1106 Oakwood Cost of project 16,800
Owner's Name MICHAEL & AMELIA FREY Address 1106 OAKWOOD AVE
Contractor BERGSTEDT BUILDERS Telephone No. 592-3451
Address 1050 Dodd St. Napoleon Ohio

PERMIT NO. _____

Lot Information: (Not required for siding job)

Lot No. 8 Subdivision J Brenmans Add
Zoning District C Lot Size (63' N.P.T.) ft. X ft. Area _____ sq. ft.
Setbacks: Front _____ Right Side _____ Left Side _____ Rear _____

Work Information:

Residential Commercial _____ Industrial _____
New Construction _____ Addition Remodel _____

Accessory Building _____ Siding Vinyl (Specific Type)

Brief Description of Work: ----- 12 foot back for Dining Room, Mud Room
Master Bed Room w/walk in closet.

Size: Length 12' Width 32' No. of Stories 1
Area: 1st Floor 384 sq. ft. Basement _____ sq. ft.
2nd Floor _____ sq. ft. Accessory Bldg. _____ sq. ft.
3rd Floor _____ sq. ft. Other _____ sq. ft.

Additional Information: _____

PERMIT FEE \$ 21.00

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date 8-29-88 Applicant's Signature Michael J. Frey

FIELD CORRECTION NOTICE

LOCATION 1106 BARWOOD PERMIT # 1106

ISSUED TO DIAGNOSTIC PRODUCTS
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO DIAGNOSTIC PRODUCTS 1000 BOOD

Upon inspection, violations of the C.A.B.C. Sec. were in

The following orders are hereby issued for their correction: REMOVE A 2'x3' STAIR

OUT MORE THAN 8 1/2" BELOW THE THRESHOLD AT

THE BACK DOOR. ALSO REMOVE STAIR STEP

UPR E1 8 1/4" MIN TOP 9"

REMOVE STAIR DETECTOR

(COPY TO MICHAEL FRY (RTVINT02))

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED ON OR BEFORE NOV 28, 1989

DATE 11-14-89 BY Erin INSPECTOR

