

1447
Doomer

Date: Aug 19, 1976

TO: Electric Distribution Superintendent

FROM: The Building Inspector - Building Department

Please confirm the installation of 200 AMP electrical service entrance, located Rear left.

at the following address: ? Oakwood.

Approved _____ Not Approved

K. C. Auz 8-19-76
Electric Supt. Date

Remarks: Underground only at that location

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement, or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name MIKE DeWit Address 175 Northcrest Dr Apt. 12D

Contractor's Name MIKE DeWit Address 145 Noetrest Dr. Tel. 599-4661

LOT INFORMATION:

Location of Project OAKWOOD AVE. Zoning District B Res.

BUILDING INFORMATION:

Single Family Double Family _____ Multiple Family _____
New Construction Existing _____ Addition _____
Replacement _____ Remodel _____ Service Change _____

Size: Total Square Foot Per Floor 1600 No. of Stories _____

DESCRIPTION OF WORK:

Size of Service 200 AMP. Service Change Only NO (Yes or No)

Total Number of New Circuits 23 Total Number of New Circuits Excluding Appliance Circuits 13

APPLIANCE CIRCUITS: (Indicate quantity)

Electric Range Range Hood Clothes Dryer Dishwasher
Air Conditioner Attic Fan Blower Room Exhaust Fan
Disposal Hot Water Heater Electric Oven _____

Require Temporary Electric YES (Yes or No) 10

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL TIE-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: \$710.00


DATE 8-17-76

APPLICANT'S SIGNATURE

Michael J. DeWit

OWNER-CONTRACTOR-AGENT

PROJECT



3-#3 THW CU 2" RIGID CONDUIT

3-3/16 THW IN. 1/2" CONDUIT
9-1-76
J.H. REF 3/10-76. U.E.C.

METER

3-#3 THW CU 1 1/2" RIGID CONDUIT

SERVICE EQUIPMENT
200A MAIN 120/240 V
1 Ø 3 WIRE - SN
WITH 20 BRANCH CKTS.
TOTAL 22 CKTS.

9-1-76 J.H. REF 250-94 W.B.C.

BARE STRANDED CU. GROUND
5/8" X 3" COPPERWELD GROUND ROD