

APPLICATION FOR PERMIT TO TAP SEWER

Owner GERMAN BUILDERS
ADDRESS 970 OAKWOOD
CONTRACTOR GERMAN BUILDERS
ADDRESS 970 OAKWOOD AVE. TEL. _____

NO. ~~557~~
BLDG. PERMIT 557
PERMIT FEE \$ 60.00
STREET BOND None
DATE PAID _____

For office use only

LOCATION OF CONNECTION

Street and No. 15 BORDEAUX Sanitary _____ Storm
Lot No. 31 Subdivision RIVIERA HTS Size of Tap 4" 6"
Size and Type of Sewer PVC ALL WORK MUST BE INSPECTED
Street to be opened-Yes _____ No _____ Opening bond fee set by Engineer \$ _____
Street opening agreement approval date _____

I certify that the sewer will be used only as indicated and no other drainage will be connected.

Date 12/14/82 Signature *Arthur W. ...*
Owner-Builder-Agent

DO NOT WRITE BELOW THIS LINE

INSPECTION RECORD

Date Inspected 12-30-82 Size and Type of Sewer 6" PVC SDR 35
Location 11.5' NORTH OF SOUTH END OF HOUSE TO M.H. IN R/W Depth 2.5' to 7' Type of Test VISUAL
Inspected and Approved by: *John Helberg* Date 12-30-82
Inspector Date

Additional information _____
Send copy to: _____

SKETCH OF INSTALLATION -ON BACK