

# PERMIT

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 36-79 Issued 4-17-79  
date

Job Location 1122 Ohio St.  
address

Lot n/a  
sub-div or legal discript

Issued By \_\_\_\_\_  
building official

Owner Howard Diemer 592-3363  
name tel.

Address 1122 Ohio St. Napoleon, Ohio

Agent Self  
builder-eng.-etc. tel.

Address \_\_\_\_\_

Description of Use New electric service & Rewire House

Residential XXX(1)  
no. dwelling units

Commercial \_\_\_\_\_ Industrial \_\_\_\_\_

New \_\_\_\_\_ Add'n. \_\_\_\_\_ Alter \_\_\_\_\_ Remodel XX

Mixed Occupancy \_\_\_\_\_

Change of Occupancy \_\_\_\_\_

Estimated Cost \$ 300.00

FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	\$5.00		\$5.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES .....			\$5.00
LESS MIN. FEES PAID _____ date _____			0
BALANCE DUE .....			\$5.00

### ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

### WORK INFORMATION:

Size: Length \_\_\_\_\_ Width \_\_\_\_\_ Stories \_\_\_\_\_ Ground Floor Area \_\_\_\_\_

Height \_\_\_\_\_ Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: New service & rewire house.  
brief description

Plumbing: \_\_\_\_\_  
brief description

Mechanical: \_\_\_\_\_  
brief description

Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_

Additional Information: ALL WORK SHALL CONFORM TO THE NATIONAL ELECTRICAL CODE 1978

EDITION, CALL FOR ROUGH-IN, SERVICE, & FINAL INSPECTIONS:

Date 4/17/79 Applicant Signature Howard Diemer  
owner

PAID  
 APR 17 1979  
 CITY OF NAPOLEON

# INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
<b>PLUMBING</b>	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
<b>MECHANICAL</b>	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
<b>ELECTRICAL</b>	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring	5-5-79	NH	<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard	5-5-79	NH	<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
<b>BUILDING</b>	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure		
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT.		
				Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued		
<b>ADDITIONAL</b>	<b>INSPECTIONS, CORRECTIONS, ETC.</b>						<b>INSPECTIONS, CORRECTIONS, ETC.</b>					

APR 15 1979  
 DIV OF INSPECTION

CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name HOWARD DIEMER Address 1122 Ohio St.

Electrical Contractor HOWARD DIEMER Telephone No. 592-3363  
Address 1122 Ohio St.

General Contractor \_\_\_\_\_ Telephone No. \_\_\_\_\_  
Address \_\_\_\_\_

Location of Project \_\_\_\_\_ Cost of Project \_\_\_\_\_

Work Information:

Residential \_\_\_\_\_ Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
No. Units \_\_\_\_\_  
New \_\_\_\_\_ Service Change  Rewiring  Additional Wiring \_\_\_\_\_

Brief Description of Work: Put service in back of house  
and running new wire in attic 12-2 with ground in the  
whole house.

Total Floor Area - Commercial and Industrial only \_\_\_\_\_ sq. ft.

Size of proposed Service Entrance \_\_\_\_\_ Number of new circuits \_\_\_\_\_

Require Temporary Electric \_\_\_\_\_ (Yes or No)

Additional Information: \_\_\_\_\_

\*GROUND-FAULT CIRCUIT INTERRUPTER PROTECTION IS REQUIRED ON ALL 120-VOLT SINGLE PHASE, 15 AND 20 AMP. CIRCUITS WHICH ARE PART OF A TEMPORARY ELECTRIC SERVICE: AND ALSO ON BATHROOM, OUTDOOR, AND GARAGE RECEPTACLES IN ALL DWELLING UNITS. Art. 210-8 N.E.C.

\*APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAYOUT AND RISER DIAGRAM. (FOR COMMERCIAL AND INDUSTRIAL WORK ONLY).

Date 4-11-79 Applicant's Signature Howard Diemer

PERMIT NUMBER

36 - 79

PERMIT FEE \$ 5.00





CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545  
(Please Print or Type)

Date .....

Permit No. 36-79

Type of Inspection SERVICE

Type of Occupancy SINGLE FAMILY

Project Name DIEMER

Address 1122 OHIO

City ..... State .....

Approved .....

Violation .....

Electrical Contractor SELF

Remarks:

Code Reference

ALSO HAS QUESTIONS ON INTERIOR  
WIRING.

Service -

① need insulating bushings in meter base & in P.H. Board.

② - #4 Bare copper ground wire to meter socket - & #4 bare copper to metal water line.

③ Interview concerning wiring with Romex.

④ use oxide inhibitor on Alum. Cond.

Compliance Time .....

Inspectors Signature M. Howes

Copies To: .....

White - Applicant

Yellow - Engineering

Pink - Electrical Inspector



CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545  
(Please Print or Type)

Date .....

Permit No. 36-79

Type of Inspection SERVICE

Type of Occupancy SINGLE FAMILY

Project Name DIEMER

Address 1122 OHIO

City ..... State .....

Approved .....

Violation .....

Electrical Contractor SELF

Remarks:

Code Reference

ALSO HAS QUESTIONS ON INTERIOR WIRING

Service -

① red insulation bushings in meter base & in Panel Board.

② - #4 Bare copper ground wire to meter socket - & #4 bare copper to metal water line.

③ Interview concerning wiring with Romex.

④ Use oxide inhibitor on Alum. Cables.

Compliance Time .....

Inspectors Signature M. Howels

Copies To: .....





CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545  
(Please Print or Type)

Date .....

Permit No. 36-79

Type of Inspection SERVICE

Type of Occupancy SINGLE FAMILY

Project Name DIEMER

Address 1122 OHIO

City ..... State .....

Approved .....

Violation .....

Electrical Contractor SELF

Remarks:

Code Reference

ALSO HAS QUESTIONS ON INTERIOR WIRING

Services -

① red insulation bushings in meter base & in Panel Board.

② - #4 Bare copper ground wire to meter socket - & #4 bare copper to metal water line.

③ Interview concerning wiring with Romex.

④ Use rods inhibitor on Drum. Cook

Compliance Time .....

Inspectors Signature J. Howell

Copies To: .....

White - Applicant Yellow - Engineering Pink - Electrical Inspector

