

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01195 Issued 7-2-86
date

Job Location 1320 Ohio
address

Lot 21 Bockleman 2nd Add.
sub-div or legal discript

Issued By Eldon Huber
building official

Owner Norman Miller 599-2400
name tel.

Address 1320 Ohio

Agent Eldor Bruns 592-1293
builder-eng.-etc. tel.

Address Rt. 5 - Napoleon, Ohio

Description of Use Residence

Residential 1
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. X Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 2,250.00

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	3.00	6.00	9.00
<input type="checkbox"/> ELECTRICAL			
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING			.00
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			9.00
LESS MIN. FEES PAID _____			
			date
BALANCE DUE.....			

ZONING INFORMATION

district A	lot dimensions 75' X 120'	area 9,000 S.F.	front yd 30' Min.	side yds 7' Min.	rear yd 15' Min.
max hgt 35' Max.	no pkg spaces 2-Min.	no ldg spaces	max cover 35%	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length 14' Width 12' Stories 1 Ground Floor Area 168
 Height 9'-6" Building Volume (for demo. permit) _____ cu. ft.

Electrical: _____
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____

Additional Information: Porch enclosure

PAID

JUL 3 1986

CITY OF NAPOLEON

Date 7-3-86 Applicant Signature Norman Miller
owner-agent

INSPECTION RECORD

	UNDERGROUND			ROUGH-IN						FINAL		
	Type	Date	By	Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING	Building Drains			Drainage, Waste & Vent Piping			Indirect Waste			Drainage, Waste & Vent Piping		
	Water Piping									Backflow Prevention		
	Building Sewer			Water Piping			Condensate Lines			Water Heater		
	Sewer Connection									FINAL APPROVAL		
MECHANICAL	Refrigerant Piping			Refrigerant Piping			Chimney(s)			Grease Exhaust System		
				Duct Furnace(s)			Fire Dampers			Air Cond. Unit(s)		
	Ducts/Plenums			Ducts/Plenums			<input type="checkbox"/> Radiant Htr(s) <input type="checkbox"/> Unit Htr(s)			Refrigeration Equipment		
				Duct Insulation			Pool Heater			Furnace(s)		
				Combustion Products Vents			Ventilation <input type="checkbox"/> Supply <input type="checkbox"/> Exhst.			FINAL APPROVAL		
ELECTRICAL	Conduits & or Cable			Conduits/Cable			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			Temp Service Temp Lighting		
	Grounding & or Bonding			Rough Wiring			<input type="checkbox"/> Generator(s) <input type="checkbox"/> Motors			Fixtures Lampholders		
	Floor Ducts Raceways			Service Panel Switchboard			<input type="checkbox"/> Water Htr <input type="checkbox"/> Welder			Signs		
	Service Conduit			Busways Ducts			<input type="checkbox"/> Heaters <input type="checkbox"/> Heat Cable			Electric Mtr. Clearance		
	Temporary Power Pole			Subpanels			<input type="checkbox"/> Duct Htr(s) <input type="checkbox"/> Furnace(s)			FINAL APPROVAL		
BUILDING	Location, Set-backs, Esmt(s)			Exterior Wall Construction			Roof Covering Roof Drainage			Smoke Detector		
	Excavation						Exterior Lath			Demolition (sewer cap)		
	Footings & Reinforcing						<input type="checkbox"/> Interior Lath <input type="checkbox"/> Wallboard					
	Floor Slab			Interior Wall Construction			Fire Wall(s)			Building or Structure	8/18	EH
	Foundation Walls			Columns & Supports			Fireplace Chimney					
	Sub-soil Drain			Crawl Space <input type="checkbox"/> Vent <input type="checkbox"/> Access			Attic <input type="checkbox"/> Vent <input type="checkbox"/> Access					
	Piles			Floor System(s)						FINAL APPROVAL BLDG. DEPT. <input type="checkbox"/>	8/18	EH
				Roof System			Special Insp Reports Rec'd			Certificate of Occupancy Issued		
INSPECTIONS, CORRECTIONS, ETC.						INSPECTIONS, CORRECTIONS, ETC.						
ALUM SIDING IN LIEU OF VINYL (GROUNDING REQ)						8/18 EH						
LABORATORY GROUNDING COMPLETE						10/7 EH						

RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON
 255 West Riverview Ave.
 Napoleon, Ohio 43545
 419/592-4010

ADDENDUM TO Permit No. 01195
 Owner NORMAN MILLER
 Contractor ELDER BROS
 Location 1720 OHIO

Please note the items checked below and incorporate them into your plans as indicated: PERMIT NOT YET ISSUED, CORRECT PLANS AND RE-SUBMIT. PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL		Show size of members supporting porch roof.
<input checked="" type="checkbox"/>	Provide approved smoke detector(s) as req'd.	Provide double top plate for all bearing partitions and exterior walls.
	Provide ½" gypsum wallboard between dwelling and garage, on garage side.	Provide design data for prefab wood truss.
	Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)	Ceiling joists undersized in <u>SEE NOTE ①</u> .
	Submit fully dimensioned plot plan.	Roof rafters undersized in _____.
	Provide min. of 1-3'0" x 6'8" exit door.	PLUMBING AND MECHANICAL
	Provide min. 22" x 30" attic access opening.	Terminate all exhaust systems to outside air.
	Provide min. 18" x 24" crawl space access opening.	Insulate ducts in unheated areas.
	Provide approved sheathing or flashing behind masonry veneer.	Provide backflow prevention device on all hose bibs.
	Provide min. 15# underlayment on roof.	Terminate pressure and temperature relief valve drain in an approved manner.
	Provide adequate fireplace hearth.	Provide dishwasher drain with approved air gap device.
	Install factory built fireplaces/stoves according to manufacturers instructions.	METAL VENEERS
	Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.	Contact City Utilities Dept. to remove conductors and/or meter.
	LIGHT AND VENTILATION	<input checked="" type="checkbox"/> Provide approved system of grounding and bonding.
	Provide mechanical exhaust or window in bathroom	ELECTRICAL
	Provide min. _____ Sq. In. net free area attic ventilation.	Show location of service entrance panel and service equipment panel.
	Provide min. _____ Sq. In. net free area crawl space ventilation.	G. F. C. I. req'd. on temporary electric.
	FOUNDATION	Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I.
	Min. depth of foundation below finished grade is 32".	Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.
	Min. size of footer _____" x _____"	Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.
	Provide anchor bolts ½" @ 6' o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.	INSPECTIONS
	Show size of basement columns.	The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs prior to the time the inspection is to be made.
	FRAMING	Footers and Setbacks. <input checked="" type="checkbox"/>
	Show size of wood girder in _____.	Foundation. <input checked="" type="checkbox"/>
	Provide design data for structural member in _____.	Plumbing rough-in. <input checked="" type="checkbox"/>
	Floor joists undersized in _____.	Plumbing final. <input checked="" type="checkbox"/>
	Provide double joists under parallel bearing partitions.	Electrical service. <input checked="" type="checkbox"/>
<input checked="" type="checkbox"/>	Provide 1" x 4" let in corner bracing, approved sheathing, or equal.	Electrical rough-in. <input checked="" type="checkbox"/>
	Show size of headers for openings over 4' wide _____.	Electrical final <input checked="" type="checkbox"/>
		Building sewer. <input checked="" type="checkbox"/>
		HVAC rough-in. <input checked="" type="checkbox"/>
		Final Building other, <input checked="" type="checkbox"/>

COMPLETED PREVIOUSLY

Additional Corrections. ① PROVIDE MIN. 2X8 ROOF JOISTS @ 16" O.C. S.I.P.F. GRADE

NO 2

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01195 and made a part there-of. DATE APPROVED OR DISAPPROVED 7-1-86 Checked by FT Plan Examiner.
 DATE RECHECKED AND APPROVED _____ Checked by _____

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01195 Issued _____ date _____

Job Location 1320 OHIO address _____

Lot 21 BOCKLEMAN 2ND ADD sub-div or legal discript _____

Issued By FA building official _____

Owner NORMAN MILLER name _____ tel. _____

Address 1320 OHIO _____

Agent ELOOR BEUWS 592-1293 builder-eng.-etc. _____ tel. _____

Address R7 5 BETHUNE NAPOLCON _____

Description of Use RESIDENCOR _____

Residential 1 no. dwelling units _____

Commercial _____ Industrial _____

New _____ Add'n. X Alter _____ Remodel _____

Mixed Occupancy _____

Change of Occupancy _____

Estimated Cost \$ 2250.⁰⁰

FEES	BASE	PLUS	TOTAL
<input checked="" type="checkbox"/> BUILDING	3.00	6.00	9.00
<input type="checkbox"/> ELECTRICAL			
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input checked="" type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW ^A	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			9.00
LESS MIN. FEES PAID _____ date _____			
BALANCE DUE.....			

ZONING INFORMATION

district <u>A</u>	lot dimensions <u>75' 120'</u>	area <u>9000 S.F.</u>	front yd <u>30' MIN</u>	side yds <u>7' MIN.</u>	rear yd <u>15' MIN.</u>
max hgt <u>35' MAX.</u>	no pkg spaces <u>2- MIN</u>	no ldg spaces	max cover <u>35%</u>	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length 14' Width 12' Stories 1 Ground Floor Area 168

Height 9'6" Building Volume (for demo. permit) _____ cu. ft.

Electrical: _____ brief description _____

Plumbing: _____ brief description _____

Mechanical: _____ brief description _____

Sign: _____ Dimensions _____ Sign Area _____

Additional Information: porch enclosure

Date _____ Applicant Signature _____ owner-agent _____

CITY OF NAPOLEON
 BUILDING INSPECTION DEPARTMENT
 APPLICATION FOR BUILDING PERMIT
 (Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 1320 Ohio Cost of project \$2250⁰⁰
 Owner's Name NORMAN Miller Address 1320 Ohio
 Contractor Eldor BRUNS Telephone No. 592-1293
 Address Rt 5 Napoleon, Ohio

Lot Information: (Not required for siding job)

Lot No. 21 Subdivision Bockleman Add. -
 Zoning District _____ Lot Size 75 ft. X 110 ft. Area _____ sq. ft.
 Setbacks: Front 26 Right Side 5'5" Left Side 16' Rear 64

Work Information:

Residential Commercial _____ Industrial _____
 New Construction _____ Addition Remodel _____
 Accessory Building _____ Siding Alum _____
 (Specific Type)

Brief Description of Work:-----

-DEPEND IN PORCH -

Size: Length 12 Width 14' No. of Stories 1
 Area: 1st Floor _____ sq. ft. Basement - sq. ft.
 2nd Floor - sq. ft. Accessory Bldg. - sq. ft.
 3rd Floor - sq. ft. Other _____ sq. ft.

Additional Information: _____

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date June 28- '86 Applicant's Signature Eldor Bruns

PERMIT NO. _____ PERMIT FEE \$ _____

RAFTERS

MIN 2x8 @ 16" O.C.

MIN GRADE SELECT STRUCTURAL

S.P.F. GRADE NO 2

26.5 x 55 1457.5

12 x 14 168

TOTAL 1625.5

LOT COURSE OK

