

**CITY OF NAPOLEON  
BUILDING CONSTRUCTION PERMIT  
(1, 2 or 3 Family Dwelling)**

Owner Name Florence Wiedmann  
 Address 516 Ohio St.  
 Builder Name Praytag Electrical Co.  
 Address 131/2 Brownell St. Tel. 599-2300

**Lot Information:**

Street No. 516 Ohio St.  
 Lot #80 Subdivision Mary Dadds 2nd Add'n  
 Lot Dimensions -- Lot Area -- Sq. Ft. --  
 Yard Set Back: Front -- Rear --  
 Side 7' Side --

Zoning "A" Intended use of Building: Installing to the west side of the existing dwelling new 100AMP service with main panel located in the basement.

**Building Information:**

Single  Double  Multiple  New Construction  Addition  Remodel   
 Size: Length          Width          No. of Stories 2  
 Floor Area: 1st Floor          2nd Floor          3rd Floor          Basement           
 Unfinished Attic          Garage           
 Foundation: Piers          Full Basement          Part Basement           
                   Concrete          Block           
 Walls: Frame          Block          Brick          Other           
 Electrical: Wiring NEW 100 AMP Electric Heating          Electrical Appliances           
 Plumbing: Fixtures or Traps          Warm Air Heating          Hot Water Heating         

Additional Information: This permit requires compliance with the attached addendum marked exhibit "A" and made a part here-of.

Date 5-1-75 Applicant Signature [Signature]  
 Owner - Builder - Agent

Permit No.	<u>210-75</u>		
Issued	<u>1/30/75</u>		
By	<u>James W. Brennan</u> Building Inspector		
Valuation	<u>\$350.00</u>		
<b>Fees</b>	<b>Base</b>	<b>Plus</b>	<b>Total</b>
Construction	<u>--</u>	<u>--</u>	<u>--</u>
Plumbing	<u>--</u>	<u>--</u>	<u>--</u>
Electrical	<u>\$3.00</u>	<u>\$3.55</u>	<u>\$6.55</u>
Heating	<u>        </u>	<u>        </u>	<u>        </u>
Water Tap	<u>        </u>	<u>        </u>	<u>        </u>
Sewer Tap	<u>        </u>	<u>        </u>	<u>        </u>
Temporary Elec.	<u>        </u>	<u>        </u>	<u>        </u>
<b>TOTAL</b>	<u>\$3.00</u>	<u>\$3.55</u>	<u>\$6.55</u>

**Inspection Record:**


Work Started          Foundations          Plumbing, Heating           
 Set Back, Side Lines          Plumbing (Rough In)          And Air Conditioning           
 Excavation          Erecting Frame          Roof           
 Footing          Electrical Work 6/12/75 disapproved by Hawes

Comments: 6/12/75 correct the following: 1) Bonded Bushing, 2) Vapor Seal, 3) Gasket for L.B., 4) thin wall for NM. cable below 7'.

Certificate of Occupancy Issued 6/13 corrected & inspected by [Signature]  
 Ink - Engineer Inspector

from the desk of-

PAUL FREYTAG



First 10 circuits \$175  
Nexted 8x60 each = \$480  
Total \$6.55

CITY OF NAPOLEON  
ENGINEERING DEPARTMENT  
APPLICATION FOR ELECTRICAL PERMIT  
(PLEASE PRINT OR TYPE)



The undersigned hereby makes application for the installation, replacement or alteration of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Code for 1, 2 and 3 Family Buildings.

Owner's Name FLORENCE WIECHMAN Address 516 Ohio St

Contractor's Name FREYTAG ELECTRIC Address 134 BROWNELL AVE Tel 599-2390

LOT INFORMATION:

Location of Project 516 Ohio St. Lot # 80

Subdivision Mary Dodd's 2nd. Zoning District \_\_\_\_\_

BUILDING INFORMATION:

Single Family  Double Family \_\_\_\_\_ Multiple Family \_\_\_\_\_

New Construction \_\_\_\_\_ Existing  Addition \_\_\_\_\_

Replacement \_\_\_\_\_ Remodel \_\_\_\_\_ Service Change

Size: Total Square Foot Per Floor \_\_\_\_\_ No. of Stories 2

DESCRIPTION OF WORK

Size of Service 100 AMP. Service Change Only \_\_\_\_\_ (Yes or No)

Total Number of New Circuits 18 Total Number of New Circuits Excluding Appliance Circuits 20  
NONE

APPLIANCE CIRCUITS: (indicate quantity)

Electric Range \_\_\_\_\_ Range Hood \_\_\_\_\_ Clothes Dryer \_\_\_\_\_ Dishwasher \_\_\_\_\_

Air Conditioner \_\_\_\_\_ Attic Fan Blower \_\_\_\_\_ Room Exhaust Fan \_\_\_\_\_

Disposal \_\_\_\_\_ Hot Water Heater \_\_\_\_\_ Electric Oven \_\_\_\_\_

Require Temporary Electric \_\_\_\_\_ (Yes or No)

Note: G.F.I.C. required for all temporary electric with approved ground rod at service.

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELECTRICAL LAY-OUT AND RISER DIAGRAM.

ESTIMATED COST OF COMPLETED PROJECT: 350.00

DATE \_\_\_\_\_ APPLICANT'S SIGNATURE [Signature]  
~~CITY~~ CONTRACTOR ~~AGENT~~