

# PERMIT

**CITY OF NAPOLEON - BUILDING DEPARTMENT**  
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01626 Issued 9-15-88 date  
 Job Location 130 Orchard Lane address  
 Lot 19 Anthony Wayne Ac. 2nd Add. sub-div or legal discript  
 Issued By Eldon Huber building official  
 Owner Mike Russell name tel.  
 Address 130 Orchard Lane  
 Agent Von Deylen Pl. & Htg. builder-eng.-etc. tel.  
 Address 116 E. Clinton  
 Description of Use Residence  
 Residential 1 no. dwelling units  
 Commercial \_\_\_\_\_ Industrial \_\_\_\_\_  
 New \_\_\_\_\_ Add'n. \_\_\_\_\_ Alter \_\_\_\_\_ Remodel X  
 Mixed Occupancy \_\_\_\_\_  
 Change of Occupancy \_\_\_\_\_  
 Estimated Cost \$ 16,878.00

FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input type="checkbox"/> ELECTRICAL			
<input type="checkbox"/> PLUMBING			
<input checked="" type="checkbox"/> MECHANICAL	18.00	46.00	64.00
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			64.00
LESS MIN. FEES PAID _____ date			
BALANCE DUE.....			

**ZONING INFORMATION N.A.**

district	lot dimensions	area	front yd	side yds	rear yd
S					
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

**WORK INFORMATION:**

Size: Length \_\_\_\_\_ Width \_\_\_\_\_ Stories \_\_\_\_\_ Ground Floor Area \_\_\_\_\_  
 Height \_\_\_\_\_ Building Volume (for demo. permit) \_\_\_\_\_ cu. ft.

Electrical: \_\_\_\_\_ brief description  
 Plumbing: \_\_\_\_\_ brief description  
 Mechanical: 2 forced air furnaces - 1-100,000 B.T.U. - 1-80,000 B.T.U. brief description  
32 hot air runs. brief description  
 Sign: \_\_\_\_\_ Dimensions \_\_\_\_\_ Sign Area \_\_\_\_\_  
 Additional Information: Refer to permit no. 01609.

**PAID**  
**SEP 15 1988**  
 CITY OF NAPOLEON

Date 9-15-88 Applicant Signature Arnold Miller owner-agent



RESIDENTIAL PLAN CORRECTION SHEET

CITY OF NAPOLEON  
255 West Riverview Ave.  
Napoleon, Ohio 43545  
419/592-4010

ADDENDUM TO Permit No. 01626 -11  
Owner MIKE RUSSELL  
Contractor VON OYCKEN PLUMBER  
Location 130 ORCHARD LAKE

Please note the items checked below and incorporate them into your plans as indicated:  PERMIT NOT YET ISSUED, CORRECT PLANS AND RE-SUBMIT.  PERMIT ISSUED, INCORPORATE ITEMS DURING CONSTRUCTION.

GENERAL			
Provide approved smoke detector(s) as req'd.		Show size of members supporting porch roof.	
Provide 1/2" gypsum wallboard between dwelling and garage, on garage side.		Provide double top plate for all bearing partitions and exterior walls.	
Provide min. 1 3/8" solid wood door from garage to dwelling. (or equal)		Provide design data for prefab wood truss.	
Submit fully dimensioned plot plan.		Ceiling joists undersized in _____.	
Provide min. of 1-3'0" x 6'8" exit door.		Roof rafters undersized in _____.	
Provide min. 22" x 30" attic access opening.		PLUMBING AND MECHANICAL	
Provide min. 18" x 24" crawl space access opening.		<input checked="" type="checkbox"/> Terminate all exhaust systems to outside air.	
Provide approved sheathing or flashing behind masonry veneer.		<input checked="" type="checkbox"/> Insulate ducts in unheated areas.	
Provide min. 15# underlayment on roof.		<input checked="" type="checkbox"/> Provide backflow prevention device on all hose bibs.	
Provide adequate fireplace hearth.		<input checked="" type="checkbox"/> Terminate pressure and temperature relief valve drain in an approved manner.	
Install factory built fireplaces/stoves according to manufacturers instructions.		Provide dishwasher drain with approved air gap device.	
Terminate chimney 2' above roof or 2' above highest point of building within 10' of chimney.		METAL VENEERS	
LIGHT AND VENTILATION		Contact City Utilities Dept. to remove conductors and/or meter.	
Provide mechanical exhaust or window in bathroom _____.		Provide approved system of grounding and bonding.	
Provide min. _____ Sq. In. net free area attic ventilation.		ELECTRICAL	
Provide min. _____ Sq. In. net free area crawl space ventilation.		Show location of service entrance panel and service equipment panel.	
FOUNDATION		G. F. C. I. req'd. on temporary electric.	
Min. depth of foundation below finished grade is 32".		Outdoor, bathroom and garage receptacles shall be protected by G. F. C. I.	
Min. size of footer _____ " x _____ ".		Maximum number of receptacles permitted on a G. F. C. I. circuit shall be 10 for 20 A. circuits and 7 for 15A. circuits.	
Provide anchor bolts 1/2" @ 6' o.c. 1' from each corner. Embedded 7" in concrete and 15" in masonry.		Refrigerators, microwaves, washers, disposal, furnace and air conditioners shall be on separate circuits.	
Show size of basement columns.		INSPECTIONS	
FRAMING		The following indicated inspections are required. The owner or his agent shall contact the City Building Dept. at least 24 hrs. prior to the time the inspection is to be made.	
Show size of wood girder in _____.		Footers and Setbacks.	Building sewer.
Provide design data for structural member in _____.		Foundation.	<input checked="" type="checkbox"/> HVAC rough-in.
Floor joists undersized in _____.		Plumbing rough-in.	Final Building
Provide double joists under parallel bearing partitions.		Plumbing final.	other,
Provide 1" x 4" let in corner bracing, approved sheathing, or equal.		Electrical service.	<input checked="" type="checkbox"/> FINAL 1/5/88
Show size of headers for openings over 4' wide _____.		Electrical rough-in.	
		Electrical final	

Additional Corrections. \_\_\_\_\_

The approval of plans and specifications does not permit the violation of any section of the Building Code or other City Ordinance. This addendum is attached to Permit No. 01626 and made a part thereof. DATE APPROVED OR DISAPPROVED 9-15-88 Checked by ELDON HOBER Plan Examiner.

DATE RECHECKED AND APPROVED \_\_\_\_\_

Checked by \_\_\_\_\_



# PERMIT

## CITY OF NAPOLEON - BUILDING DEPARTMENT

01626 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No.                      Issued 9-15-88  
date

Job Location 130 ORCHARD CARR  
address

Lot 19 ROYALTY WAY, AC, 2<sup>ND</sup> ADD  
sub-div or legal descrip

Issued By FH  
building official

Owner MIKE ROSSELL  
name tel

Address 130 ORCHARD LANE

Agent VON DEYLAN PLYMOUTH  
builder-eng-etc tel

Address 116 E. CLINTON

Description of Use RESIDUICK

---

Residential 1  
no dwelling units

Commercial            Industrial           

New            Add'n.            Alter            Remodel X

Mixed Occupancy           

Change of Occupancy           

Estimated Cost \$ 16,878.<sup>00</sup>

FEES	BASE	PLUS	TOTAL
<input type="checkbox"/> BUILDING			
<input type="checkbox"/> ELECTRICAL			
<input type="checkbox"/> PLUMBING			
<input checked="" type="checkbox"/> MECHANICAL	18. <sup>00</sup>	46. <sup>00</sup>	64. <sup>00</sup>
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. <u>          </u> hrs	Elect. <u>          </u> hrs	
TOTAL FEES.....			64. <sup>00</sup>
LESS MIN. FEES PAID <u>          </u>			
BALANCE DUE.....			

### ZONING INFORMATION

district <u>5</u>	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

### WORK INFORMATION:

Size: Length            Width            Stories            Ground Floor Area           

Height            Building Volume (for demo. permit)            cu. ft.

Electrical:            brief description

Plumbing:            brief description

Mechanical: 2 - FORCED AIR FURNACES 1-100,000 B.T.U. 1-50,000 B.T.U.  
brief description 32 - HOT AIR RONS

Sign:            type            Dimensions            Sign Area

Additional Information: REFER TO PERMIT N° 01609

Date            Applicant Signature            owner-agent





CITY OF NAPOLEON  
BUILDING INSPECTION DEPARTMENT  
APPLICATION FOR HEATING PERMIT  
(PLEASE PRINT OR TYPE)

The undersigned hereby makes application for the installation, replacement or alteration of a heating system or device as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Mechanical Code for 1, 2 and 3 Family Buildings.

Owner's Name MIKE ROSSELL Address 130 ORCHARD LAKE

Contractor's Name DON DEYLEN PARKER Address 116 CLINTON Tel. 592-4756

BUILDING INFORMATION:

Single Family  Double Family \_\_\_\_\_ Multiple \_\_\_\_\_ New Construction \_\_\_\_\_

Addition \_\_\_\_\_ Remodel  Replacement \_\_\_\_\_ No. of Stories \_\_\_\_\_

DESCRIPTION OF WORK

Heating System - Warm Air  Hot Water \_\_\_\_\_ Steam \_\_\_\_\_ Electric \_\_\_\_\_

Unit Heaters \_\_\_\_\_ Unit Gas Heaters \_\_\_\_\_ Other \_\_\_\_\_

Type - Gravity \_\_\_\_\_ Forced  Radiant \_\_\_\_\_

No. of Thermostatical Heating Zone \_\_\_\_\_

Hot Water - One Pipe \_\_\_\_\_ Two Pipe \_\_\_\_\_ Series Loop \_\_\_\_\_

Electric Heat - No. of Circuits \_\_\_\_\_ Other \_\_\_\_\_

Total Heat Loss of Area to be Heated 172,659 Btu.

Rated Capacity of Furnace/Boiler \_\_\_\_\_ Btu.

No. of Furnaces 2 No. of Hot Air Runs 32

No. of Hot Water Radiators \_\_\_\_\_ Type of Fuel NAT GAS

Heating Units Located: Crawl Space \_\_\_\_\_ Floor Level  Suspended \_\_\_\_\_

Roof or Exposed to Outside Air \_\_\_\_\_ Attic \_\_\_\_\_ Other \_\_\_\_\_

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: LOCATION OF FURNACE OR UNIT HEATERS AND SIZE AND LOCATION OF FEEDER DUCTS AND RETURN AIR DUCTS. ALL PLANS SHALL BE DRAWN TO SCALE.

ESTIMATED COST OF COMPLETED PROJECT: 16,878<sup>00</sup>

DATE 9-15-87 APPLICANT'S SIGNATURE Ornold Miller

OWNER-CONTRACTOR-AGENT

