

140 ORCHARD LN

=== Line Inspection Report ===

25JUL01 02:49PM

Darrs Cleaning Inc.
Clyde, OH
<800> 541-DARR
--- LOCATION HEADER ---
CUSTOMER...:Napoleon
LOCATION... :
STREET.....:Orchard Ln
START MH...:145 Orchard
END MH :125 Orchard
TAPE BEG/EN:00:00/06:30

----- LINE DATA -----
PIPE TYPE...:concrete
SURFACE :roadside
INSP LENGTH:198 ft
SEWER TYPE.:sanitary
SEWER SIZE.:8 in
REPORT NO. :1
OPERATOR...:Roger Darr
FLOW.....:with
DIRECTION...:south

Record: 001
0197.9F
Record: 002
0197.9F

manhole at 125 Orchard,tap right,mh leaking
no taps on this stretch of sewer