

May 24, 1993

Marc Gerken, City Engineer
City of Napoleon
W. Riverview
Napoleon, Ohio 43545

Dear Marc:


Early in January we talked on the phone about some water problems at 205, 215 and 235 Orchard Lane with sanitary and storm sewers.

Since I have not heard from city operations on when they might cut a work order for this area, I am sending you a reminder.

1. The sanitary sewer concrete cover is off the manhole at 205 Orchard Lane. This allows surface water to run in.
2. In checking the eastbound outlet at this location, 205 Orchard, the outlet appears to be blocked by bricks and pieces of concrete.
3. Joe Miller, my neighbor, and I checked the storm and sanitary sewers at 235 Orchard Lane and it appears that those lines were never separated as the other were in Anthony Wayne Acres. This should be corrected, if so.
4. All of Orchard Lane sanitary sewers should be cleaned and power flushed. It's been a long time since anyone has done it.

Thank you for your consideration.

Respectfully,



Bob Baker
215 Orchard Lane

cc/Mayor Lankenau
cc/City Operations,
Jeff Marihugh