



CITY OF NAPOLEON

ENGINEERING DEPARTMENT

255 West Riverview Avenue, P. O. Box 151 Napoleon, OH 43545

Chad E. Lulfs, P.E., P.S., City Engineer

Telephone: 419/592-4010 Fax: 419/599-8393

www.napoleonohio.com

August 23, 2007

Todd Slight
270 Orchard Lane
Napoleon, OH 43545

Re: Down Spouts

Dear Mr. Slight,

It has come to our attention that you recently directed your downspouts through the City of Napoleon's right-of-way and into the street. This is not allowed. All downspouts must be directed across a grassed area prior to reaching a hard surface. In general, a minimum of five (5) feet of grassed area is required. However, private lines are not allowed to be placed in public right-of-way without a permit.

Please remove the portion of this line that is presently located within the City of Napoleon's right-of-way. The City of Napoleon's Engineering Department must be contacted prior to working in the right-of-way. If you have any questions or require additional information, please contact our office

Yours truly,

Chad E. Lulfs, P.E., P.S.
City of Napoleon Engineer

cc: Dr. Jon A. Bisher, City Manager
Rex Moll, Construction Inspector

