


PARK ST.

SHEFFIELD ST.


PARK CT.



TRIM TREES
AS NEEDED

CHANGE #4 COPPER
LINE SECONDARYS
WITH 2/0 TRIPLEX

REPLACE ALL OPEN
WIRE DROPS WITH
TRIPLEX X



Napoleon Power & Light

1775 Industrial Drive Napoleon, Ohio

ITEM 4 PARK CT.

DATE 8/20/93 W.O.# 30706 J.O.# J01252 DRAWN BY MTD