



CITY OF NAPOLEON

ENGINEERING DEPARTMENT
255 West Riverview Avenue, P. O. Box 151, Napoleon, OH 43545
Chad E. Lulfs, P.E., P.S., City Engineer
Telephone: 419/592-4010 Fax: 419/599-8393
www.napoleonohio.com

October 30, 2007

918 Park Street
Napoleon, OH 43545

Attn: Steve Duryea

Re: Storm Sewer Revisions
Final Notice

Dear Mr. Duryea,

The City of Napoleon recently inspected the property at 918 Park Street and the required storm sewer modifications have not been completed. The City of Napoleon, Ohio Engineering Department Rules & Regulations, Section 4.1.6, Storm Sewer Sizing, prohibits connections of downspouts (roof drains) to storm sewers. The required modifications to the existing storm sewer are as follows:

1. The storm sewers protruding from the ground for downspout connections shall be removed down to the wye connection and permanently plugged with a glued cap.
2. All work shall be inspected by the City of Napoleon's Engineering Department. No work shall be backfilled prior to an inspection.
3. All work shall be completed within fourteen (14) days from the date of this letter.

This letter shall serve as your final notice for this matter. If work has not been properly completed and inspected within fourteen (14) day from the date of this letter, this matter shall be forwarded to the City of Napoleon's Law Director. Please note this violation is a misdemeanor offense. If you have any questions or require additional information, please contact our office.

Yours truly,

A handwritten signature in cursive script, appearing to read "Chad E. Lulfs".

Chad E. Lulfs, P.E., P.S.
City of Napoleon Engineer

cc: Dr. Jon A. Bisher, City Manager
David Grahn, City Law Director
Rex Moll, Construction Inspector