

P E R M I T

CITY OF NAPOLEON  
255 W. RIVERVIEW AVE  
NAPOLEON, OHIO 43545

DIVISION OF BUILDING & ZONING  
PH (419) 592-4010  
FAX (419) 599-8393

PERMIT NO: 1822

DATE ISSUED: 08-20-03

ISSUED BY: TJK

JOB LOCATION: 918 PARK ST

EST. COST: 4000.00

LOT #:

SUBDIVISION NAME:

OWNER: LUEPP, GREG  
ADDRESS: 918 PARK ST  
CSZ: NAPOLEON, OH 43545  
PHONE:

AGENT: BOB CORDES PLUMBING  
ADDRESS: 17-706 CO RD Q-1  
CSZ: NAPOLEON, OH 43545  
PHONE: 419-758-3162

USE TYPE - RESIDENTIAL:

OTHER:

ZONING INFORMATION

DIST: LOT DIM: AREA: FYRD: SYRD: RYRD:  
MAX HT: # PKG SPACES: # LOADING SP: MAX LOT COV:

BOARD OF ZONING APPEALS:

WORK TYPE - NEW: REPLMNT: ADD'N: ALTER: REMODEL:

WORK INFORMATION

SIZE - LGTH: WIDTH: STORIES: LIVING AREA SF:  
GARAGE AREA SF: HEIGHT: BLDG VOL DEMO PERMIT:


WORK DESCRIPTION  
WATER SERVICE RPLC

FEE DESCRIPTION	PAID DATE	FEE AMOUNT DUE
PLUMBING PERMIT		9.00

TOTAL FEES DUE 9.00

Aug 20, 2003  
DATE

[Signature]  
APPLICANT SIGNATURE



Sketch

CITY OF NAPOLEON

WATER METER YOKE RELEASE FORM

THIS DOCUMENT ENTITLES THE HOLDER TO "ONE" WATER METER YOKE ASSEMBLY  
(Please pickup at City Operations Department 1775 Industrial Drive).

PERMIT #: 1822

ISSUED: 08-20-2003

JOB LOCATION: 918 PARK ST

OWNER: LUEPP, GREG

PHONE:

ADDRESS: 918 PARK ST NAPOLEON, OH 43545

-----  
CONTRACTOR: BOB CORDES PLUMBING

ADDRESS: 17-706 CO RD Q-1 NAPOLEON, OH 43545

PHONE: 419-758-3162

WATER TAP SIZE 1"  1.5" \_\_\_\_\_ 2" \_\_\_\_\_ OTHER \_\_\_\_\_

WATER METER YOKE SIZE 5/8"  3/4" \_\_\_\_\_ 1" \_\_\_\_\_ OTHER \_\_\_\_\_

NEW STRUCTURE \_\_\_\_\_ EXISTING STRUCTURE  LAWN METER \_\_\_\_\_

WATER SERVICE LINE TO BE TYPE "K" COPPER OR "CTS" POLYETHELENE TUBING OF 1" MINIMUM SIZE.

BACKFLOW DEVICE REQUIRED YES  NO \_\_\_\_\_

TYPE OF BACKFLOW DEVICE REQUIRED Double check valve assembly.

WATER METER YOKE INSTALLATION IS SUBJECT TO THE FOLLOWING CONDITIONS

- 1.) MUST BE LOCATED IN AN ACCESSIBLE AREA.
- 2.) MUST BE IN AN AREA WHICH IS NOT SUBJECT TO FREEZING TEMPERATURES.
- 3.) MUST BE AT LEAST 18" ABOVE FLOOR LEVEL (NO CRAWL SPACE INSTALLATIONS).
- 4.) MUST COMPLY WITH MINIMUM MOUNTING REQUIREMENTS (DRAWING AVAILABLE)

ISSUED BY \_\_\_\_\_ RECEIVED BY \_\_\_\_\_

1-Copy to: Building Dept, Water Dept, and Utilities Dept