

CITY OF NAPOLEON
BUILDING CONSTRUCTION PERMIT

Owner Name William Datsor
 Address 1005 N. Perry St.
 Builder Name Bergstedt Builders Inc.
 Address 1050 Dodd St. Tel. 592-3151

Lot Information:

Street No. 1005 N. Perry St.
 Lot 21 Subdivision J. James Lot. Addn.
 Lot Dimensions _____ Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Sidewalk ~~required in accordance with Ordinance~~
 No. _____

*Installing new 100AMP service entrance onto the existing storage warehouse.
 LOCATED IN "C" ZONE*

Building Information:

Residence _____ Commercial _____ Industrial _____
 Single _____ Double _____ Multiple _____ New Construction _____ Addition _____ Remodel _____
 Size: Length 16' Width 24' No. of Stories 2
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical Outlets: 120v *NEW 100AMP SERVICE* 240v
 Plumbing: Fixtures _____ Traps _____ Vents _____ Heating _____ Air Conditioning _____

Additional Information: *This permit requires compliance with the attached electric wiring exhibit "A" and made a part hereof.*

Date 2/14/75 Applicant Signature [Signature]
 Owner - Builder - Agent

Inspection Record:

Work Started _____ Foundations _____ Plumbing, Heating _____
 Set Back, Side Lines _____ Plumbing (Rough In) _____ And Air Conditioning _____
 Excavation _____ Erecting Frame _____ Roof _____
 Footing _____ Electrical Work _____

Comments: *S.E. inspection of items inspected & approved by N. Howes 2/20/75 requiring correction conducted by [Signature]*

Certificate of Occupancy Issued _____

Pink - Engineer

Inspector


Permit No. <u>702-75</u>				
Issued <u>2/14/75</u>				
By <u>[Signature]</u>	Building Inspector			
Estimated Cost <u>1350.00</u>				
	Fees	Base	Plus	Total
Construction				
Basement				
Detached Garage				
Plumbing				
Electrical		<u>\$18.00</u>		<u>\$18.00</u>
Heating				
Air Conditioning				
Water Tap				
Sewer Tap				
Temporary Electric				
Total FEE		<u>\$18.00</u>		<u>\$18.00</u>
LESS MINIMUM FEE PAID				<u>\$18.00</u>
AMOUNT DUE				<u>NONE</u>

Willis Moten
Setmer

For
Bergstedt Bldg.
Don Bergstedt

CITY OF NAPOLEON
ENGINEERING DEPT.
PLAN APPROVAL
BY: N.A. DATE: 2/1/73

RECEIVED
FEB. 1 3 1973
J.W.P.



alley

alley

Burger
Chief

2 miles
2" 24" Rigid Conduit 10' long
to SER
Aidm wire

46' 0" Clearance over
Publ. Street 16'-18'
7'

24

DATE	2-20-75		JOB NO.	203-75	
PROJECT	STORAGE WAREHOUSE				
LOCATION					
CONTRACTOR			OWNER		
WEATHER			TEMP.	° at	AM
				° at	PM
PRESENT AT SITE					

TO

Lewis Detmer (592-3451)
 1005 N. Perry St.
 Napoleon, O.

Not approved 2/20/75

THE FOLLOWING WAS NOTED

① Ground Neutral Bus BAR to PNL. ENCLOSURE. Art. 250 NEC

② Service Box ON 2" CONDUIT AT Roof LINE. Art-300-NEC

③ Install 3/4" Gnd Pipe @ 18" A.F.G. AND EXTEND GROUND WIRE TO CHAMP. Art-250 NEC

④ Secure Gnd wire to SURFACE upon which it is Attached. Art. 300 NEC

⑤ Provide (1) ADDITIONAL CONDUIT support @ 18" Above meter enclosure Art 300 NEC.

Copy to Mr. [unclear] 2/20/75
 [unclear]

FIELD REPORT

SIGNED M. Hous
 Elect. Insp.

CITY OF NAPOLEON WORK ORDER

No 15995

Dept. Electric

Name Willis Detmer

Date Ordered 2-25-75

Address 1005 N. Perry St. (Storage Warehouse @ rear of lot.)

By Don Bergstedt

LOCATION	Remove			Install		
	No.	Date	Rdg.	No.	Date	Rdg.
Electric						
Water						
Water Hr.						

Request: Hook-up New 100 AMP Service. Ken, ok to hook-up
passed electrical inspection 2/24/75/cm.

Date CompletedBy

Date

Mr. Brown offered the following Resolution:-

Resolution.

to trans-
funds.

Resolved by the Council of the Village of Napoleon, Ohio, that whereas, as there is a surplus of \$1000.⁰⁰ in the Marshal Fund of said Village, which surplus arose from the New Tax, that, therefore, said sum of \$1000.⁰⁰ be and the Clerk and Treasurer of said Village are hereby directed to transfer said \$1000.⁰⁰ to the Fire Fund of said Village, to be used for the purposes of said Fire Fund.

The Roll Call on the adoption of the above Resolution was as follows: Ayes: Messrs. Booker, Gilson, Huddle, Knape, Pohlman and Brown; Nays: None. The Mayor declared the Resolution adopted.

Henry Rohrer asked that Council lay a six inch tile drain on east side of Scott street from Clinton Street to catch basin in alley first north of Clinton Street. Moved by Mr. Huddle that the matter be referred to the Sewer Com. with power to act. The motion was sec. by Mr. Knape and carried by the following vote: Ayes: Messrs. Booker, Gilson, Huddle, Knape, Pohlman and Brown; Nays: None.

Mr. Brown offered the following Resolution:

Resolution.

apurch
plies

Resolved by the Council of the Village of Napoleon, Ohio, that 35 standard fireman's coats, guaranteed water proof, at a cost of \$133 and 18 rubber hats at a cost of \$18 and one lot of one helmet at a cost of \$4.⁰⁰ be purchased from Henry Meyer.


The Resolution was adopted by the following vote: Ayes: Messrs. Booker, Gilson, Huddle, Knape, Pohlman and Brown; Nays: None. The Mayor declared the Resolution adopted.

alley vaca-
tion

Mr. Gilson moved that the alley between Lots Nos. 2, 3, 4, 5 & 6 in John Knape's 1st addition, be and the same is hereby vacated. The motion was sec. by Mr. Booker and adopted by a full affirmative vote of Council.

The Fire and Water Com. Mr. Gilson reported that two new watering troughs were needed, one at corner of Clinton and Scott Streets and one on South Side.

Mr. Gilson moved that the Clerk receive sealed bids up to next regular meeting for furnishing and placing two watering troughs, said troughs to be placed at such points as may hereafter be agreed upon by the Fire and Water Com. The motion was sec. by Mr. Booker and carried by a full



(For Field Notes See Page 180)

Recd:
Henry
P.M.
Geo. S

The above is a true transcription of the foregoing plat as same appears in Vol. 2 Page 161