

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. 883
Job Location 1008 North Perry Street Valuation \$ 91,000.00
Address
Owner Napoleon V. F. W. Address 1008 North Perry Street
Name
Contractor Custom Agri Systems Inc. Telephone No. (419) 762-5180
Address/Route 424 West Napoleon, Ohio
Electric Contractor _____
Plumbing Contractor _____
Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential _____ Commercial A3 Industrial _____
No. dwelling units
New Construction _____ Addition XXXXX Remodel _____
Brief Description of Work Multi-purpose Room Addition with Lobby and storage for tables and chairs

ISSUED BY Richard G. Wayman DEPT. OF BUILDING & ZONING
Building Official

PAID

AUG 13 1984

It is the owners or contractors responsibility to call the Building Department for the following (X) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES CITY OF NAPOLEON

Building Permit	\$ <u>92.61</u>
Electrical Permit	\$ _____
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other	\$ _____

TOTAL FEES \$ 92.61
LESS FEES PAID \$ _____
BALANCE DUE \$ 92.61

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

Faint header text at the top of the page, possibly containing a title or reference number.

385

A block of faint text in the middle of the page, possibly a paragraph or a list of items.

959

28 1 1 1 1 1

1 1 1 1 1 1 1

Faint text on the right side of the page, possibly a date or a signature.

Faint text at the bottom of the page, possibly a footer or a page number.

CITY OF NAPOLEON
 BUILDING INSPECTION DEPARTMENT
 APPLICATION FOR BUILDING PERMIT
 (Please print or type)

The undersigned hereby makes application for construction, installation, or alteration work as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Building Codes.

Location of project 1008 North Perry Street Cost of project \$91,000.00
 (total)
 Owner's Name Napoleon V. F. W. Address 1008 N. Perry St.
 Contractor Custom Agri Systems Inc. Telephone No. (419) 762-5180
 Address Rt. 2 424 West Napoleon, Ohio

Lot Information: (Not required for siding job)

Lot No. _____ Subdivision _____
 Zoning District _____ Lot Size _____ ft. X _____ ft. Area _____ sq. ft.
 Setbacks: Front _____ Right Side _____ Left Side _____ Rear _____

Work Information:

Residential _____ Commercial A-4 (OBBC) Industrial _____
 New Construction _____ Addition XXXXXXXXXXXXXXXXXX Remodel _____
 Accessory Building _____ Siding 26 gage metal panel
 (Specific Type)

Brief Description of Work: ----- Multi-purpose room addition w/ lobby & storage
for tables and chairs

Size: Length 65 ft. 0 in width 72 ft. 3 in No. of Stories 1 (one)
 Area: 1st Floor 5,219 sq. ft. Basement 0 (zero) sq. ft.
 2nd Floor 0 (zero) sq. ft. Accessory Bldg. 0 (zero) sq. ft.
 3rd Floor 0 (zero) sq. ft. Other 0 (zero) sq. ft.

Additional Information: 4757 sq ft
44

APPLICATION FOR PERMIT SHALL BE ACCOMPANIED BY TWO COMPLETE SETS OF PLANS INCLUDING: ELEVATIONS, FLOOR PLANS, CROSS SECTIONS AND PLOT PLAN. IF ADDITION OR REMODELING, SHOW ALL EXISTING STRUCTURES AND THEIR SIZE AND LOCATION. ALL PLANS SHALL BE DRAWN TO SCALE.

Date 2/13/84 Applicant's Signature [Signature]

883
 9261

PERMIT

CITY OF NAPOLEON, OHIO — DEPT. OF BUILDING & ZONING
255 W. Riverview Avenue, Napoleon, Ohio 43545 (419) 592-4010

Permit No. _____ Date 13 Aug 84

Job Location 1008 North Perry Street Valuation \$ 91,000.00

Owner Napoleon V. P. W. Address 1008 North Perry Street

Contractor Custom Agri Systems Inc. Telephone No. (419) 762-5180

Address Route 424 West Napoleon, Ohio

Electric Contractor _____

Plumbing Contractor _____

Mechanical Contractor _____

This permit is issued for work described in the plans, specifications, and/or application submitted, as approved by the Building Commissioner of the City of Napoleon, Ohio. Work shall conform to all pertinent construction and land use Codes and Ordinances.

Work Information:

Residential No. dwelling units _____ Commercial A3 Industrial _____

New Construction _____ Addition XXXX Remodel _____

Brief Description of Work Multi-purpose Room Addition with Lobby and Storage for Tables and chairs

ISSUED BY _____ Building Official _____ DEPT. OF BUILDING & ZONING

PAID
AUG 13 1984
CITY OF NAPOLEON

It is the owners or contractors responsibility to call the Building Department for the following (x) inspections:

- Footing excavation prior to placing concrete.
- Footing drains and foundation prior to backfill.
- Prepared sub-grade prior to placing concrete floor slab.
- Sanitary sewer
- Rough-in electrical, plumbing and service framing prior to installing wall board.
- Final electrical, plumbing and heating.
- Final building inspection, prior to occupancy.

PERMIT & FEES

Building Permit	\$ <u>92.61</u>
Electrical Permit	\$ _____
Plumbing Permit	\$ _____
Mechanical Permit	\$ _____
Demolition Permit	\$ _____
Zoning Permit	\$ _____
Sign Permit	\$ _____
Water Tap	\$ _____
Sewer Tap	\$ _____
Temp. Elec.	\$ _____
Other _____	\$ _____
TOTAL FEES	\$ <u>92.61</u>
LESS FEES PAID	\$ _____
BALANCE DUE	\$ <u>92.61</u>

Permit is not valid until all fees are paid in full, and shall be void if work is not started within six months of date above.

INSPECTION RECORD

UNDERGROUND			ROUGH-IN			FINAL		
Type	Date	By	Type	Date	By	Type	Date	By
PLUMBING								
Sewer Connection			Drainage, W. & Vent	11/14/84	PKB	Drainage, W. & Vent		
Building Sewer			Water Piping			Water Heater		
Water Piping			Condensate Lines			Backflow Prevention		
			Indirect Waste					
						FINAL APPROVAL		
Floor Ducts Raceways			Rough Wiring	11/14/84	PKB	Electric Mtr. Clearance		
Conduits & Cable			Conduits/Cable			Signs		
Grounding & Bonding	11/16/84	PKB	Service Panel Switchboard	11/16/84	PKB			
SPOT Check	11/26/84	PKB	Subpanels					
			<input type="checkbox"/> Range <input type="checkbox"/> Dryer			FINAL APPROVAL		
ELECTRICAL								
Refrigerant Piping			Refrigerant Piping			Duct Insulation		
Ducts/Plenums			Ducts/Plenums			Chimney(s)		
			Ventilation Supply			Furnace(s)		
			<input type="checkbox"/> Exhst.			FINAL APPROVAL		
MECHANICAL								
Location, Set-backs, Esmt(s)			Wall Construction	11/26/84	PKB	Fireplace Chimney		
Excavation			Crawl Space			Attic		
Footings & Reinforcing			<input type="checkbox"/> Vent <input type="checkbox"/> Access			<input type="checkbox"/> Vent <input type="checkbox"/> Access		
Sub-soil Drain			Floor System(s)			Special Insp Reports Rec'd		
Foundation Walls			Roof System			Smoke Detector		
Floor Slab			Fire Wall(s)	11/16/84	PKB	Demolition (sewer cap)		
			Roof Cover/ Roof Drain			Building or Structure		
FINAL APPROVAL BLDG. DEPT			FINAL APPROVAL			Certificate of Occupancy Issued		#

11/2/84 Handicap Bathroom
 11/5/84 Handicap Bathroom w/ van
 11/12/84 General insp
 11/13/84 " " (1) Stop occupancy
 11/16/84 " " " "
 1/2/85 Roof started on front



City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010
NAPOLEON, OHIO 43545-0151

November 13, 1984

Mayor
Robert C. Heft

V.F.W.
1008 N. Perry
Napoleon, OH 43545

Clerk-Treasurer
Robert W. Schweinhart

Re: VFW Occupancy Certificate

Members of Council
Darel Aust, Miller, President
William Young
Evelyn Haase
Dorrell Fox
Donald Morford
Lynn Wachtmann

City Manager
Richard A. Hayward

Law Director
Keith E. McCallister

Dear Boardmembers:

It has come to the City of Napoleon's attention that a Bingo Feather Party was held in the new facilities at the rear of the VFW.

An Occupancy Certificate has not been issued on the new building, as of yet. The following items must be completed before occupancy would be granted:

1. Exit lights in and working.
2. Ceiling is fire-rated and shall be completed and all tiles in place.
3. All lights shall be in place and working.
4. All electrical boxes and equipment shall have covers and equipment in place.
5. Ventilation and heating shall be in and working.
6. All construction equipment shall be placed in an out of the way location and be roped or fenced so no one may reach it.

No function shall take place until these items are completed and authorization is received from the Building Commissioner or the City Engineer.

Your cooperation is requested in this matter.

Yours truly,

Richard G. Hayman
Building Commissioner

RGH:dd

VFW Women Restroom



