

FIELD CORRECTION NOTICE

LOCATION 1012 N. Perry PERMIT NO. 02339

ISSUED TO Alan Von Dyken
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO Same as above address

Upon inspection, violations of the N.E.C Sec. _____ were in evidence.

The following orders are hereby issued for their correction: Base Copper ground to

connect from metal base through conduit into new
indoor panel.

Correct to be changed every 2'
also 2" mast conduit to be
using 2 hole straps with lag bolts (not spike

Call Me at City Building 572-4010

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 6-19-91

DATE 6-18-91 BY Don M. [Signature] INSPECTOR

PINK - ORIGINAL COPY WHITE - FIELD COPY YELLOW - FILE COPY

FIELD CORRECTION NOTICE

LOCATION 1012 N. Perry PERMIT NO. 00339

ISSUED TO Alan Von Dillen
PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO Same as above address

Upon inspection, violations of the N.E.C Sec. _____ were in evidence.

The following orders are hereby issued for their correction: Bare copper ground to

connect from meter base through conduit into new

indoor panel. Conduit

also 2" mast conduit to be changed every 2'

using 2 hole straps with lag bolts (not spikes)

BE -
Call Me at City Building 572-4010

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 6-19-91

DATE 6-18-91 BY Paul M... INSPECTOR

PINK - ORIGINAL COPY WHITE - FIELD COPY YELLOW - FILE COPY

METER SOCKET RELEASE

Entry No. _____ issued by
The Napoleon Electric Distribution Department
639 Industrial Drive Napoleon, Ohio 43545 Pn. 592-9116 or 592-4010

Permit No. 008791 Issued 6-12-91 Building permit No. 02339 Job Address 1012 N. Perry

Lot Number 17 Sub Division J. Knaps 1st

Owner Doug Willemson Owners Address 1476 Oakwood Ave Pn. No. 599-5710

Contractor Alan Vandylka Contractors Address 850 Strong St Pn. No. 592-4386

Size of Service 200 Overhead Underground _____ Issued By Burt Dammann

Date completed _____ Approved by _____

Size of Service _____ Overhead _____ Underground _____ Street and No. _____ electric distribution dept.

Old Meter No. _____ New Meter No. _____ Remarks _____

Sketch of Service

Grid area for sketching service details.