

City Of Napoleon
FIELD SURVEY FORM

Mailng address
P.O. Box 408
Napoleon, Ohio 43512

Premises Address: 485 N. Perry Company Name: Napoleon Wash & Fill
Contact Name: Mike Snyder Contact Phone No: 592-0851
Service No: 3942 Service Size: 2" Meter No: 9305081 Meter Size: 2" Date Installed: 10-8-83
Type of Inspection: Initial Follow-Up Date of Inspection: 12-9-97 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 8" System Pressure 65-70 psi
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity _____

INSPECTOR COMMENTS/DIAGRAMS

3- 5 gal. buckets for detergent feed, fill line below flood rim
2- stainless steel reservoirs, fill line below flood rim
25 gal. barrel for chassis wash, fill line below flood rim
9- injection pumps, rust inhibitor, detergent, wax, etc.
boiler for heating water for car washing or chemicals added

FIRE PROTECTION SYSTEMS

System Type: Dry Sprinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: _____ (GPM) Pressure: _____

INSPECTOR COMMENTS/DIAGRAMS

R.P.A. Reduced Pressure Assembly

BACKFLOW PREVENTION REQUIREMENTS

at least a 2" reduced pressure assembly must be install after your water meter
4" may want to consider a 2 1/2" device depending on your water demand