

APPLICATION FOR PLAN REVIEW
 CITY OF NAPOLEON
 ELECTRICAL PERMIT
~~BUILDING CONSTRUCTION PERMIT~~

Owner Name NAPOLEON WASH-N-FILL, INC.
 Address 485 North Perry Street
 Builder Name SPEISER ELECTRIC
 Address CO. RD. # 16, Napoleon, O. Tel. 599-1846

Lot Information:

Street No. 485 North Perry Street
 Lot 133-A Subdivision Third Addition
 Lot Dimensions _____ Lot Area _____ Sq. Ft.
 Yard Set Back: Front _____ Rear _____
 Side _____ Side _____

Sidewalk required in accordance with Ordinance
 No. _____

Building Information:

Residence _____ Commercial X _____ Industrial _____
 Single _____ Double _____ Multiple _____ New Construction _____ Addition _____ Remodel _____
 Size: Length _____ Width _____ No. of Stories _____
 Floor Area: 1st Floor _____ 2nd Floor _____ 3rd Floor _____ Basement _____
 Unfinished Attic _____ Garage _____
 Foundation: Piers _____ Full Basement _____ Part Basement _____
 Concrete _____ Block _____
 Walls: Frame _____ Block _____ Brick _____ Other _____
 Electrical Outlets: 120v _____ 240v _____
 Plumbing: Fixtures _____ Traps _____ Vents _____ Heating _____ Air Conditioning _____
 Additional Information: To install a new auto vacuum system

Date 7/11/74 Applicant Signature Michael L. Doyle
 Owner - Builder - Agent

This permit shall be void six months after date of issue unless construction shall have been started. Application for Permit shall be accompanied by two complete sets of plans including: Elevations, Floor Plans, Specifications, Plot Plans and such other information as the Building Inspector may require.

Any substantial alteration of plans covered by this Permit may be made only by written permission of the Building Inspector.

No part of any building area authorized by this Permit may be occupied until final inspection and issuance of a Certificate of Occupancy by the Building Inspector. Building Permit card shall be posted conspicuously by job site during construction.

APPLICATION
 PERMIT No. 80 E
 Issued _____
 By _____
 Building Inspector
 Estimated Cost _____

*Permit # 80E
 Issued 7-16-74*

Fees	Base	Plus	Total
Construction			
Basement			
Detached Garage			
Plumbing			
Electrical	18.00		18.00
Heating			
Air Conditioning			
Water Tap			
Sewer Tap			
Temporary Electric			
Total	MINIMUM FEE		\$ 18.00

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name NAPOLEON WASH. N. FILL, INC
Address 485 NORTH PERRY STREET
Builder Name SPEISER ELECTRIC
Address Co. Rd. #14, NAPOLEON, O. Tel. 579-1846

Permit No. 80 E
Issued July 14, 1974
By Robert C. Jones Building Inspector
Estimated Cost \$1,000

Lot Information:

Street No. 485 NORTH PERRY STREET
Lot 133-A Subdivision THREE ADDITIONS
Lot Dimensions Lot Area Sq. Ft.
Yard Set Back: Front Rear Side Side

Sidewalk required in accordance with Ordinance No.

Building Information:

Residence Commercial Industrial
Single Double Multiple New Construction Addition Remodel
Size: Length Width No. of Stories
Floor Area: 1st Floor 2nd Floor 3rd Floor Basement
Unfinished Attic Garage
Foundation: Piers Full Basement Part Basement
Concrete Block
Walls: Frame Block Brick Other
Electrical Outlets: 120v 240v
Plumbing: Fixtures Traps Vents Heating Air Conditioning
Additional Information: ELECTRICAL INSTALLATION FOR NEW AIR CONDITIONING SYSTEM

Date Applicant Signature Owner - Builder - Agent

Inspection Record:

Work Started Foundations Plumbing, Heating
Set Back, Side Lines Plumbing (Rough In) And Air Conditioning
Excavation Erecting Frame Roof
Footing Electrical Work

Comments:

Certificate of Occupancy Issued

Pink - Engineer

Inspector

Table with columns: Fees, Base, Plus, Total. Rows include Construction, Basement, Detached Garage, Plumbing, Electrical, Heating, Air Conditioning, Water Tap, Sewer Tap, Temporary Electric, Total.


NAPOLEON WORKS
ELECTRICAL SUPPLY
NEW NAPOLEON SYSTEM

7-1-74

#5 3/4 IN. DIAMETER

#4 1/2 IN. DIAMETER

#3 1/2 IN. DIAMETER



SIZE 2 BE. MAGNETIC
MOTOR STARTER

P.R. STATION



10HP 240 VOLT 3PH
2950 RPM MOTOR



3" 1/2 IN. COPPER IN EXISTING CONDUIT

ELECTRICAL TO BE INSTALLED IN
ACCORDANCE WITH NATIONAL ELECTRICAL
CODE LATEST EDITION.

RCS

JIM SPEISEL ELECTRIC

R. R. 2 BOX 201

PH. 592-1826 NAPOLEON, OHIO 43545

CITY OF NAPOLEON

115 W. Main St.

NAPOLEON, OHIO 43545

message

reply

to: [Jim Speiser Electric
R.R. #2

[Napoleon, Ohio 43545

subject Elect. Inspection, Napoleon Wash-N-Fill Inc.
Permit No. 80E

ON Friday, July 19, 1974, an
inspection was conducted on the
installation for a new auto vacuum
cleaner system and the following
conditions were noted:

1. Outside @ junction box near
system, plug hole.
2. Inside @ main panel re-install
cover which is off. *How done*

date July 25, 1974 signed City Building Inspector date signed

RECEIVER: Reply, retain white copy, return pink copy.

SENDER: Mail white and pink copies with carbon intact.
33990. Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

CITY OF NAPOLEON
115 W. Main St.
NAPOLEON, OHIO 43545

RECEIVED
reply

message

to: Jim Speiser Electric

R.R. #2

Napoleon, Ohio 43545

subject Elect. Inspection, Napoleon Wash-N-Fill Inc.
Permit No. 80E

Mr. Tomas Terranova
Inspection Dept.
City Building, Napoleon, O.

Tom;

Completed installation

on Conveyor Chain Alarm and
buttoned up panel and KO plug
at pull box 8/17/74

ON Friday, July 19, 1974, an
inspection was conducted on the
installation for a new auto vacuum
cleaner system and the following
conditions was noted:

1. Outside @ junction box near system, plug hole.
2. Inside @ main panel re-install cover which is off. *James Brown*

date 8/30/74 signed *Tom Speiser*

RECEIVED: Reply, retain white copy - return photo copy

QDER: All white and pink copies with carbon in set.
33296, American Printing and Litho Corp., Amsterdam, N.Y. 12010