

**City Of Napoleon**  
**FIELD SURVEY FORM**

Premises Address: 501 N. Perry Company Name: Speedway  
Contact Name: Karen Herrera Contact Phone No: 592-0433  
Service No: 7160 Service Size: 1" Meter No: 242243 Meter Size: 3/8" Date Installed: 1-5-99  
Type of Inspection: Initial  Follow-Up  Date of Inspection: 1-22-99 Inspector Name: Chloe  
Type of Use: Industrial  Commercial  Residential  Water Main Size: 8" System Pressure 65 PSI  
Type of Service: Domestic  Fire  Combined  Any Other Water Source: Yes  No   
If Yes, Other Type: Additional City Service  Auxiliary Source  Interconnected: Yes  No   
\*\*\*\*\*

**DOMESTIC SYSTEMS**

Type of Use: Processing  Product  Potable  Sanitary  Irrigation  Limited Area Fire   
Type of Heating: Forced Air  Electric  Solar  Boilers  Chemical Treatment: Yes  No   
Type of Cooling: Cooling Tower  Chiller  Chemical Treatment: Yes  No  Direct Conn: Yes  No   
Dishwasher: Yes  No  Eductors: Yes  No  Garbage Disposal: Yes  No  Jacuzzi: Yes  No   
Swimming Pool: Yes  No  Air Gap at Supply: Yes  No  Pumps Used: Yes  No  Capacity

**INSPECTOR COMMENTS/DIAGRAMS**

1. 1/2 to Soda Fountain  
automate water to coffee & Cappuccino machine  
ice maker  
2. sinks in front  
slip sink w/ hose below floor rim for soap bucket  
2. bathroom

**FIRE PROTECTION SYSTEMS**

System Type: Dry Spinkler  Wet Sprinkler  Dry Riser  Wet Riser  Hydrants: Yes  No   
Hydrants Self-Draining: Yes  No  Storage Provided: Yes  No  Antifreeze Legs: Yes  No   
Auxiliary Water Storage: Yes  No  Pumps Used: Yes  No  Capacity:  (GPM) Pressure:

**INSPECTOR COMMENTS/DIAGRAMS**

no expansion tanks  
  
need to install a R.P.Z.A Device, and Expansion Tank

**BACKFLOW PREVENTION REQUIREMENTS**

These devices need to be made accessible for testing