

FIELD CORRECTION NOTICE

LOCATION 506 Perry Street North PERMIT NO. NA

*Norm Bostelman 5/20*

ISSUED TO Vernon Moler

PERMIT HOLDER AND/OR ALL RESPONSIBLE PARTIES.

NOTICE DELIVERED TO Norm Bostelman, Electrical Contractor

Upon inspection, violations of the Napoleon Code of Ordinances Sec. 150.06-B were in evidence.

The following orders are hereby issued for their correction: Obtain a permit for a service change at job location. Change service to 100 amp 240 Volt service. Locate meter and disconnect on outside of structure. Make these changes within 30 days of written notice.

PLEASE CALL FOR INSPECTION WHEN CORRECTIONS HAVE BEEN COMPLETED. ACCEPTANCE AND APPROVAL BY AN INSPECTOR OF THIS DEPARTMENT IS REQUIRED AND MUST BE CORRECTED

ON OR BEFORE 20 June 86 *D. NE Bostelman*