

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Tina's Pizzeria, Inc.  
Address 836 Highland Drive  
Builder Name Rupp Lumber Co.  
Address Pettisville, Ohio, 43553 Tel. 445-7891

599-3966

Lot Information:

Street No. 617 North Perry Street  
Lot 5 Subdivision Original Plat 1st Add  
Lot Dimensions ..... Lot Area ..... Sq. Ft. .....  
Yard Set Back: Front ..... Rear .....  
Side ..... Side .....

**MODELING THE EXISTING 43'x 61' BUILDING INTO PIZZA RESTAURANT.**  
Sidewalk required in accordance with Ordinance

No. ....

Building Information: CHAPTER BB-67 OF O.B.C.  
LOCATED IN A "GB" ZONE

Residence ..... Commercial X Industrial .....

Single ..... Double ..... Multiple ..... New Construction ..... Addition ..... Remodel .....

Size: Length 43' Width 61' No. of Stories 2

Floor Area: 1st Floor 2,623sqft 2nd Floor ..... 3rd Floor ..... Basement .....

Unfinished Attic ..... Garage .....

Foundation: Piers ..... Full Basement ..... Part Basement .....

Concrete ..... Block ..... Brick .....

Walls: Frame ..... Block ..... Brick .....

Electrical Outlets: 120v ..... 240v .....

Plumbing: Fixtures ..... Traps ..... Vents ..... Heating ..... Air Conditioning .....

Additional Information: This permit requires compliance with the attached letter

No. 9040-MJ-N-16 and the attached addendum marked exhibit "A" and made a part of this permit.

Date 11-15-75 Applicant Signature [Signature]

Note: Informed Rupp Lumber First cuts required in Owner - Builder Agent all structural lumber embedded into masonry wall. Aug 12/5/75

Inspection Record: Sec. BB-7-06.01

Work Started 12/1/75 Foundations ..... Plumbing, Heating .....

Set Back, Side Lines ..... Plumbing (Rough In) ..... And Air Conditioning .....

Excavation ..... Erecting Frame ..... Roof .....

Footing ..... Electrical Work .....

Comments: 12/15/75 meeting today with Carey & Bob Sames. 2-layers of 5/8" x gypsum board. No-protek Gilder. Also provide Pultex 8-layers ladder for ready access to 2nd floor. SWP.

Certificate of Occupancy Issued on 12/17/76, No. 049 by [Signature] Inspector

Pink - Engineer

Permit No. 308-75

Issued 12/1/75

By [Signature] Building Inspector

Estimated Cost 249,000.00

Fees ..... Base ..... Plus ..... Total .....

Construction .....

Basement .....

Detached Garage .....

Plumbing .....

Electrical .....

Heating .....

Air Conditioning .....

Water Tap .....

Sewer Tap .....

Temporary Electric .....

Total Fees 125,000.75

LESS MINIMUM FEES PAID 11/7 182.35  
AMOUNT DUE 125,000.75

Basement 2/476 Type D hardware on front door. Informed Carter provide permanent sign read "The door shall not require the use of a key" Other ducting business bars. Aug 12/5/75

Date: 1-5-76

TO: The Building Inspector - Engineering Dept.

FROM: Electric Distribution Superintendent

Confirmed the installation of 200 AMP. electrical  
service entrance, located TINY PIZZA Parlor

3 & 240 Delta  
at the following address: N. Perry

Approved  Not Approved

K. E. Raup  
Electric Supt.

January 5 - 1976  
Date

Remarks: Wants 225 Amp Service but 200 socket will take overload  
for that small amount.

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Mingle Pass, Inc.
Address 836 Highland Drive, Maumee, O.
Builder Name Eldon Roth Electric
Address Archbold, Ohio, 43502 Tel. 445-6406

Lot Information:

Street No. 617 North Perry Street
Lot 5 Subdivision Original Plat 1st Add
Lot Dimensions Lot Area Sq. Ft.
Yard Set Back: Front Rear
Side Side

REMODELING THE EXISTING 43'x 61' BUILDING INTO PIZZA RESTAURANT, Sidewalk required in accordance with Ordinance

Building Information: CHAPTER BE-67 OF O.B.C. LOCATED IN A "GB" ZONE

Residence Commercial

Single Double Multiple New Construction Addition Remodel

Size: Length 43' Width 61' No. of Stories 2

Floor Area: 1st Floor 2,623 sq. ft. 2nd Floor 2,623 sq. ft. 3rd Floor Basement

Unfinished Attic Garage

Foundation: Piers Full Basement Part Basement

Concrete Block

Walls: Frame Block Brick Other

Electrical Outlets: 120v 225AMP, 3-Phase 240v

Plumbing: Fixtures Traps Vents Heating Air Conditioning

Additional Information: This permit requires compliance with the attached letter No. 388-75L and the attached addendum marked exhibit "A" and made a part hereof.

Date 1/18-75 Applicant Signature Approved by Howes, ID of Conductors had to be corrected, Owner - Builder - Agent

Inspection Record: 2/26/76 Final Elect. Tested and Approved by Howes Plumbing, Heating

Work Started Foundations

Set Back, Side Lines Plumbing (Rough In) And Air Conditioning

Excavation Erecting Frame Roof

Footing Electrical Work 1/8/76 Rough-in only approved by Howes.

Comments: Note 1/8/76 can not ground to street side of water line, because plastic water pipe used

Certificate of Occupancy Issued

Pink - Engineer

Inspector

Permit No. 200-75

Issued 1/15/75

By Building Inspector

Estimated Cost \$19,000.00

Fees Base Plus Total

Construction

Basement

Detached Garage

Plumbing

Electrical

Heating

Air Conditioning

Water Tap

Sewer Tap

Temporary Electric G.P.I.C. REQUIRED

Total FEES \$19,000.00

LESS MINIMUM FEES PAID 11/7 \$32.

AMOUNT DUE \$18,968.00

February 6, 1976

Tiny's Pizza, Inc.  
836 Highland Drive  
Wauseon, Ohio 43567

Attention: Mr. Paul Weber and Stu Wyse

Gentlemen:

In reference to our meeting today, your actions were uncalled for and offensive. The City of Napoleon has appointed me to enforce all adopted codes, not to take verbal abuse from you or anyone else. As a matter of suggestion I recommend you reconsider your approach not only with me, but with any other public official you may have to conduct business with. Bear in mind Gentlemen, that cooperation is a two-way street.

Unintentionally I misinformed you when I made the statement that the only means of altering or over-riding my decisions in regards to code requirement pertaining to exit signs was to appeal to the State Board of Building Standards. Mr. Robert Jones, P.E., of the Engineering Department, is the Chief Enforcement Official pertaining to the Ohio Building Code. If you so desire, a meeting can be arranged with you and Mr. Jones by contacting him at this phone number - 592-5771.

If you have any questions please feel free to contact me at the City Building or call 592-4010.

Sincerely,

Thomas W. Terranova  
Building & Zoning Inspector  
Engineering Department

TWT/cv

cc: Robert Jones  
Roy Dorsey

ENGINEERING DEPARTMENT  
INTEROFFICE COMMUNICATION

Date Jan 8, 1976

To: Engineering From: Tom T.

Subject: Conversation Today with Electrician And Carty

~~2/26/76~~  
1) Provide illuminated Exit signs @ the Following Locations: Door No. 2, 3, 5 and directional @ the passageway from <sup>Storage</sup> ~~Storage~~ Rm. to Lobby. Also in Storage Rm. provide directional sign ~~IF~~ walk-in cabler blocks vision of ~~apex~~ means of exiting, ~~by sign~~

2) At Doors No. 4 & 5 Provide a permanent sign on Pin Ball Rm. side of Door # reading "No Exit" & on Door No. 5 on Lobby side provide sign readings its actual character (sign indicating its actual character) ~~(Refer To Life Safety Code NFPA 101 Sec. 5-1112)~~

~~3) Both Bath Rm. provide Mechanical ventilation to outside.~~

~~4) Non absorbing materials in both Bath Rms,~~

~~5) Plywood Floor in Storage Rm ok,~~

~~Approved by sign~~

**FLOYD G. BROWNE AND ASSOCIATES, LIMITED**  
CONSULTING ENGINEERS-PLANNERS

9040-MI-N-16  
City of Napoleon Plan Review

November 17, 1975

Mr. Pritam Arora  
Building Commissioner  
City of Napoleon  
City Building  
Napoleon, Ohio 43545

SUBJECT: TINY'S PIZZA

Dear Mr. Arora:

I have reviewed the plans prepared by Rupp Lumber Company for compliance with Chapter BB-67 Mercantile Buildings and have approved the plans with the following conditions:

1. Doorway No.3 and the passageway from the dining room to the lobby shall have installed a direction of travel sign Type D.
2. Doorways No.1 and No.2 shall require Type A exit signs.
3. Doors No.4 and No.5 should have a clear panel to eliminate the possibility of using these doors as means of egress.


If there are any questions feel free to call.

Very truly yours,

FLOYD G. BROWNE AND ASSOCIATES, LIMITED

*Robert C. Jones*  
Robert C. Jones, P.E.  
Chief Enforcement Official

RCJ/fbh



CITY OF NAPOLEON  
ENGINEERING DEPT.  
PLAN APPROVAL

BY: *B.J. Puz* DATE: *11/17/75*

MARION OFFICE  
181 South Main Street  
P.O. Box 587  
Marion, Ohio 43302  
614-383-2187

\* NORTHWESTERN OFFIC  
703 North Perry Street  
P.O. Box 27  
Napoleon, Ohio 43545  
419-592-5771

EASTERN OFFICE  
5276 Fulton Drive  
Canton, Ohio 44718  
216-494-3324

INDIANA OFFICE  
Suite 501, First Savings T  
P.O. Box 1218  
Anderson, Indiana 46015  
317-644-3676

YOUNGSTOWN OFFICE  
25 East Boardman  
Youngstown, Ohio 44503  
216-747-3175

MEMBERS

E. B. Butler, P.E.  
T. J. Dunn, Sr. P.E.  
R. C. Jones, P.E.  
M. L. Koehler, P.E.  
H. R. Lloyd, P.E.  
C. R. Martin, P.E.  
L. E. Rigby, P.E.  
D. L. Tesmer, P.E.  
C. W. Wright, P.E.

ASSOCIATES

R. M. Blank, P.E.  
G. G. Geis, A.I.P.  
R. L. Haas, C.E.T.  
W. R. Hill, C.E.T.  
J. M. Keevil, P.E.  
T. Kraschinsky, Jr., P.E.  
R. C. Lewis  
D. E. Mackling, P.E.  
A. P. Manatekar, P.E.  
J. E. Miller, P.E.  
H. L. Mumaw, P.E.  
J. Y. Roberson, P.E.  
F. X. Waldo, P.E.

Floyd G. Browne and  
Associates, Limited is  
an equal opportunity  
employer

\*ADDRESS REPLY TO THIS OFFICE

CITY OF NAPOLEON

Engineering Department

ELECTRICAL INSPECTION FIELD REPORT

255 Riverview Avenue Napoleon, Ohio 43545

(Please Print or Type)

Project Name TIKVS PIZZA INC.

Address 617 N. Perry St.

City Napoleon State Ohio

Approved

Violation

Electrical Contractor

Eldon Roth Electric

Remarks: Plan Review 11-9-75

Code Reference

1. Electric wiring, equipment & installation shall conform to the requirements of National Electric Code NEPA-70-1975 and is subject to the approval of the City Electrical Inspector.

2. All abandoned wiring in existing facility to be removed. Art. 110-12 N.E.C.

3. Fluorescent fixtures are not to be attached to combustible materials. Refer to overhang detail. Art. 410-76(b) NEC

4. Hazardous conditions in basement & attic wiring are to be corrected.

5. Load conditions are not shown, size of circuits, feeders & service are predicated on facility load.

6. Type of wiring metal raceway.

Compliance Time

Inspectors Signature

Letter No 380-751

Norman Ansel

Copies To:

White - Applicant

Yellow - Engineering

Pink - Electrical Inspector



FLOYD G. BROWNE AND ASSOCIATES, LIMITED  
 CONSULTING ENGINEER - PLANNER  
 MARION, OHIO

Engineering Dept  
**RECEIVED**  
 NOV 19 1975

MEMO TO Tom Terranova DATE 11.17.75

SUBJECT Plan Review Time Schedule JOB NO. \_\_\_\_\_

FROM Robert C. Jones / fbh TITLE \_\_\_\_\_

Plan Review on Universal Cooperatives, Inc. 1 Hr.

Plan Review on Tiny's Pizza 1 Hr.

*Submitted to  
 Pritam 11/18/75  
 by f.w.f*



TELE: 6 34314

# AMBRIC TESTING ASSOCIATES, INC.

REGISTERED ENGINEERS  
• INSPECTORS •



TESTING LABORATORIES  
• CHEMISTS •

240 MARKET ST.  
AST PATERSON, N. J. 07407  
201-BW 7-8883

3600 CRAWFORD STREET  
PHILADELPHIA, PENNA. 19129  
GERMANTOWN 8-2688

506 SOUTH DUPONT HWY  
DOVER, DELAWARE 19001  
302-734-0010

# RECEIVED

FEB 9 1976

CITY OF NAPOLEON  
ENGINEERING DEPT.  
*[Signature]*

*[Handwritten signature]*

Coronet Industries, Inc.  
P. O. Box 1248  
Dalton, Georgia 30720

Attn: Mr. Larry Whitener

Lab. No.: 12284  
P. O. No.: 25400

Gentlemen:

The following is a report of the results of a flame spread Tunnel Test performed on a sample submitted to us by you. The report contains a description of the material, the preparation of the test sample, the test procedure, and the test results. The results presented apply only to the specimen tested and not necessarily to the entire production of this or similar materials.

The test was conducted in accordance with ASTM: E 84-70, "Surface Burning Characteristics of Building Materials."

The purpose of the test is to evaluate the performance of a material in relation to the performance of asbestos-cement board and select red oak flooring under similar fire exposure. The results are in terms of flame spread, fuel contributed and smoke developed during a 10 minute exposure and are numerically expressed as a ratio with asbestos-cement board zero and red oak flooring 100. Periodic calibration tests using select red oak flooring and a 10 minute test with asbestos-cement board prior to each test series establish the basic reference data.

3000 CRAWFORD STREET  
PHILADELPHIA, PENNA. 19129  
215-408-7941

Time, MINUTES

TEMPERATURE, DEGREES FAHRENHEIT



Location

Sample  
RICK HARRIS

Contractor  
RICK HARRIS

Job No. 12951 Date 1-4-73

Note:  
FUEL CONTRIBUTION



**Coronet**  
CARPETS

COMMERCIAL CARPET DIVISION

**NEWS**

*1/23/76 For test data reports 1-copy  
asked for f.w.f.*

*Engineers Dept*  
**RECEIVED**  
JAN. 23 1976  
*Paul*

THE FOLLOWING IS A CURRENT LIST OF CORONET QUALITIES TESTED IN ACCORDANCE WITH ASTM-E 84 (STEINER TUNNEL TEST)

QUALITY	FLAME SPREAD RATE	FUEL CONTRIBUTED FACTOR	SMOKE DENSITY FACTOR
022	Action Line/J-----59	51	64
	Action Line/R-----31	38	119
462	Adornment/J-----74	37	160
029	Anchorloc/J-----46	45	59
527	Berber Tuft/J-----75	27	124
500	Bright Delight/J-----33	1	170
442	Bronco/J-----56	55	83
570	Cantina/J-----75	27	124
524	Caribea/J-----81	29	119
Q18/218	Chesley/J-----15	50	105
511	Coral Palms/J-----31	22	115
505	Critic's Choice/J-----36	1	50
406	Cypress Point/J-----75	100	160
587	Dehli/J-----89	37	194
435	Diamond Rock/J-----56	39	52
316	Electra/J-----75	65	150
053	Executive Tower/J-----36	20	157
440	Gold Cup/J-----81	62	79
033	Maharaja/J-----56	22	197
550	Montego/J-----70	37	59
030	Passport/J-----56	37	151
487	Rock Rib/J-----28	30	130
106/306	Senate/J-----36	17	71
112	St. Claire/J-----31	28	175
521	Stampede/J-----59	52	70
388	Triplet/S-----70	50	135
422	Ultimate/J-----41	2	155
247	-----67	45	80

CLASS A 0-25  
CLASS B 26-75  
CLASS C 76-200

0-50  
51-125  
126-200

# Coronet

CARPETS

Division of CORONET INDUSTRIES, INC. PRODUCTS FOR TOTAL ENVIRONMENTS

CORONET DRIVE ■ DALTON, GEORGIA 30720 ■ (404) 278-1255

ENGINEERING Dept.  
**RECEIVED**  
JAN 23 1976  
*Paul*

October 13, 1975

## 029 ANCHORLOC SPECIFICATIONS

Construction  
Type Face Yarn

Level Loop  
100% Antron Nylon/With  
Antron III Static Control

Yarn Size  
Coloration  
Pile Height/ASTM D-418  
Stitches Per Inch  
Tufts/Sq. Inch  
Tufts/Sq. Yard  
Gauge

2450 Denier  
Multi-color, Space Dyed  
.133  
9.8  
98  
127,008  
1/10

Static Resistance  
Density Factor  
Weight Density Factor  
Pile Weight  
Primary Backing  
Secondary Backing (Jute)  
Secondary Backing (High Density  
Foam)

Below 2.5 Kilovolts @ 70° F 20% Humidity  
5,414  
108,280  
20 oz. per Sq. Yd.  
Polypropylene, 3 oz. per Sq. Yd.  
7 oz. per Sq. Yd.  
38 oz. per Sq. Yd. "F" Standard Foam

Total Weight (Jute)  
Total Weight (High Density  
Foam)

60 oz. per Sq. Yd.  
81 oz. per Sq. Yd. "F" Standard Foam

FURTHER INFORMATION OR SPECIFICATIONS WILL BE SUPPLIED ON REQUEST.

November 11, 1975

Tiny's Pizza, Inc.  
836 Highland Drive  
Wauseon, Ohio 43567

Attention: Mr. Steward Wyse

Dear Mr. Wyse:

In reference to our conversation at my office on November 7, 1975, the proposed location at 617 North Perry Street is within a "GB" General Business District. The establishing of a pizza shop or restaurant is permitted use in this zoning district.

Since the proposed Tiny's Pizza, Inc. will be located in an existing building in the downtown area, no additional off-street parking is required.

If you have any other questions, please feel free to call.

Sincerely,

Thomas W. Terranova  
Building & Zoning Inspector  
Engineering Department

TWT/cv

COPY



Tiny's Pizza Inc.  
Wauseon, Ohio 43567

September 18, 1975

Appeals Board  
City of Napoleon  
Napoleon, Ohio

Gentlemen:

Tiny's Pizza Inc. wishes to open a pizza shop in Napoleon to be located on the west side of Perry Street across from the courthouse in the building now occupied by Hoy Clothing.

Our hours will be as follows:

Monday	Closed
Tues, Wed, Thursday	5:00 p.m. - 12:00 p.m.
Friday	5:00 p.m. - 1:00 a.m.
Saturday	2:00 p.m. - 1:00 a.m.
Sunday	5:00 p.m. - 12:00 p.m.

We are not a complete service restaurant. We specialize in pizza. Our peak business hours are after 9:00 p.m.

We have downtown locations on the main street in Wauseon, Bryan, and Archbold. About 40% of our business is carryout, and the customer is in the restaurant only about three minutes.

Respectfully submitted,

Tiny's Pizza Inc.

9/22/75 Presented a copy of this letter  
to Board of Zoning Appeals. They did  
not believe a Variance was warranted, P.W.S.  
For off street parking because of hours.  
9/23/75 Informed City Wyse No Variance in Zoning  
Required. P.W.S.



**CITY OF NAPOLEON**  
 NAPOLEON, OHIO 43545

**0095**

56-516  
 412

COMMUNITY BANK  
 NAPOLEON, OHIO

PAY

DATE | AMOUNT  
 October 6, 1975 | \$25.00

\* Tiny's Pizzas, Inc.  
 Wauseon, Ohio 43567

CITY OF NAPOLEON, OHIO

**COPY - NON-NEGOTIABLE**

AUTHORIZED SIGNATURE

PLEASE DETACH BEFORE DEPOSITING

IN PAYMENT OF		ACCOUNT CHARGEABLE		0095
DATE	INVOICE NO.	AMOUNT	DEPARTMENT	ACCOUNT NO. AMOUNT
	and on Receipt 57 of 9-16-75 for ing fee for variance onings. No hearing ired.	\$25.00	General Fund Revenue	\$25.00

CITY OF NAPOLEON, OHIO

No. ....049.....

CERTIFICATE OF OCCUPANCY  
THE CITY OF NAPOLEON

ENGINEERING DEPARTMENT  
DIVISION OF INSPECTION

This is to certify that the Building or Land as herein described complies with all the building and health laws and ordinances and with the provisions of the Zoning Ordinance.  
617 N. Perry St.  
Restaurant - 1st Floor  
Location of Occupancy (existing building) Occupancy (BB-67 of O.B.C.)

Owner of Property Tiny's Pizza, Inc.  
Address 836 Highland Drive  
Wauseon, Ohio 43567  
Issued to Tiny's Pizza, Inc.  
Address 836 Highland Drive  
Wauseon, Ohio 43567  
Zoning "GB" General Business Bldg. Permit No. 388-75

Substantial qualifications of occupancy Attached and made a part hereof.

This certificate is issued by the City Building Inspector, as provided by law, and is to certify that construction is completed substantially in conformity with the approved plans and permission is hereby granted to occupy such building in compliance with such legal use and occupancy as authorized under the provisions of the ordinances of the City of Napoleon.

Issued this 27th day of February, 1976

Signed *Tom M. Jones*  
City Building Inspector  
This is a valuable record for owner or lessee and should be so preserved.





FROM THE DESK OF ... *Tiny*  
**RECEIVED**

APR 12 1976

CITY OF NAPOLEON  
ENGINEERING DEPT.

BY: *F.W.P.* April 8, 1976

Mr. Thomas W. Terranova  
Building & Zoning Inspector  
City of Napoleon, Engineering Dept.  
255 Riverview  
Napoleon, Ohio 43545

Re: Your letter of 2/27/76

Dear Mr. Terranova:

We have made an effort to correct Item #1, but have not been able to, due to this sign being out of stock at the Hardware.

Item #2 has been corrected completely.

Item #3, we have installed the oven hood and system in complete agreement with the terms of the listing and/or approved design, in accordance with NFPA Standard #96. Section BB-67-37.

Thank you for your patience in this matter.

Sincerely,

A handwritten signature in cursive script that reads "Paul J. Weber".

Tiny  
Tiny's Pizza Inc.

February 27, 1976

Substantial Qualifications of Occupancy  
Tiny's Pizza Restaurant  
Certificate of Occupancy No. 049

Tiny's Pizza, Inc.  
836 Highland Drive  
Wauseon, Ohio 43567

This Substantial Qualifications of Occupancy is attached and made a part hereof. The following items require your attention:

1. Installation of a permanent-type sign in clear lettering not less than one eighth of an inch in height and reading, "THE OPENING OF THIS DOOR FROM THIS SIDE SHALL NOT REQUIRE THE USE OF A KEY DURING BUSINESS HOURS", shall be attached on the interior side of Door No. 1.  
Section BB-67-13 of O.B.C.
2. Door No. 4 and No. 6 which is so located or arranged as to be likely to be mistaken for an exit, shall be identified by a permanent-type sign reading "NOT AN EXIT" or similar designation or shall be identified by a sign indicating its actual character, such as, "WOMEN'S ROOM", "STORAGE ROOM", or the like. Signs shall be in plain legible letters not less than 4 1/4 inches high with the principal strokes of letters not less than 3/4 inch wide. Section BB-67-18.
3. The installer and/or owner shall certify in writing to the Engineering Department of Napoleon, that the installation of the oven hood and system is in complete agreement with the terms of the listing and the manufacturer's instructions and/or approved design in accordance with NFPA Standard No. 96. Section BB-67-37.

8/12/76  
Dink

RECEIVED

*L.P.D.*  
MAR 3 1976

ENGINEERING DEPARTMENT

INTEROFFICE COMMUNICATION

CITY OF NAPOLEON  
ENGINEERING DEPT.

Date

3/4-3-76

To: Tom Terranova From: J. E. Funchey, Capt.

Subject: Tully's Digger, Inc. 617 N. Rang St.

Fire inspection made 3-2-76 found that one 2 $\frac{3}{4}$  LBS. ABC Extinguisher is needed on second floor for the Electric Furnace. One 5 lbs ABC Extinguisher is needed in the basement for the 2 gas Furnaces.

A C O can be given provided they complete the above and the No. 1 and 3 of your items that you look out for. They have completed No. 2.

John E. Funchey  
Fire Inspector