

City Of Napoleon
FIELD SURVEY FORM

620
Premises Address: 111 N. Perry Company Name: Courthouse
Contact Name: Dorothy Taylor Contact Phone No: 592-8973
Service No: 1938 Service Size: 4" Meter No: 7002758 Meter Size: 2" Date Installed: 7-24-97
Type of Inspection: Initial Follow-Up Date of Inspection: 2-2-99 Inspector Name: Charlie
Type of Use: Industrial Commercial Residential Water Main Size: 3" System Pressure
Type of Service: Domestic Fire Combined Any Other Water Source: Yes No
If Yes, Other Type: Additional City Service Auxiliary Source Interconnected: Yes No

DOMESTIC SYSTEMS

Type of Use: Processing Product Potable Sanitary Irrigation Limited Area Fire
Type of Heating: Forced Air Electric Solar Boilers Chemical Treatment: Yes No
Type of Cooling: Cooling Tower Chiller Chemical Treatment: Yes No Direct Conn: Yes No
Dishwasher: Yes No Eductors: Yes No Garbage Disposal: Yes No Jacuzzi: Yes No
Swimming Pool: Yes No Air Gap at Supply: Yes No Pumps Used: Yes No Capacity

INSPECTOR COMMENTS/DIAGRAMS

soap eductors at stop sink for filling soap bucket
2 pumps for boilers run 1 at a time 50 psi Exp. 96 gpm Hot water
softener plumbed up to lines not using though
boiler feed lines also have RPZA device on them
2 pump cold water side of boilers 35 psi
expansion tank @ hot water tank

FIRE PROTECTION SYSTEMS

System Type: Dry Spinkler Wet Sprinkler Dry Riser Wet Riser Hydrants: Yes No
Hydrants Self-Draining: Yes No Storage Provided: Yes No Antifreeze Legs: Yes No
Auxiliary Water Storage: Yes No Pumps Used: Yes No Capacity: (GPM) Pressure:

INSPECTOR COMMENTS/DIAGRAMS

4" 2000 55 AMES DCA on fireline, is sufficient
Both Devices need Tested a.s.a.p.
2" zurn-wilkins RPZA on table is sufficient

BACKFLOW PREVENTION REQUIREMENTS

2 pumps on chiller 50 psi tank room w/sink
8- drinking fountains
2- hot water bibbs
23- bathrooms