


Temporary Certificate of Occupancy

Wood County Building Inspection

<p>Address: BRICK N BREW PUB 631 NORTH PERRY NAPOLEON, OH 43545 County: Henry Approved As:</p>	<p>Stipulations, Conditions, & Variances: Temporary Occupancy Approved for 30 Days Items to be Completed: 1. Cover Exposed foam board in both existing basement areas. 2. Duct Return Air for Existing Furnace in Basement Area, and Terminate in Habitable Space on First Floor. 3. Provide Mechanical Plans, submit for review/approvals for Type II Hood added over 4 burner range. Temporary Occupancy Expires on July 15, 2013. Maximum Occupancy is 99.</p>												
<table border="1" style="width: 100%; border-collapse: collapse;"> <thead> <tr> <th style="width: 30%;">Use Groups:</th> <th>Occupancy Description:</th> </tr> </thead> <tbody> <tr> <td>Primary</td> <td>A-2 Bar/Restaurant</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Accessory</td> <td>0</td> </tr> <tr> <td>Mixed Use</td> <td>0</td> </tr> </tbody> </table> <p>Attached Floor Plan: <input type="checkbox"/></p> <p>Construction Type: 3B</p>	Use Groups:	Occupancy Description:	Primary	A-2 Bar/Restaurant	Accessory	0	Accessory	0	Accessory	0	Mixed Use	0	<p>This Certificate represents an approval that is valid only when the building and its facilities are used as stated and is conditional upon all building systems being maintained and tested in accordance with the applicable Ohio Board of Building Standards rules and applicable equipment or systems schedules. This certifies conformance with Chapters 3781 and 3791 of the Ohio Revised Code and the applicable provisions of the rules of the Ohio Board of Building Standards.</p>
Use Groups:	Occupancy Description:												
Primary	A-2 Bar/Restaurant												
Accessory	0												
Accessory	0												
Accessory	0												
Mixed Use	0												
<table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%;">System Type: N/A</td> <td style="width: 50%;">Demand:</td> </tr> <tr> <td>Standpipe:</td> <td>Demand:</td> </tr> <tr> <td colspan="2">Location:</td> </tr> </table> <p>Specific Hazards: Storage of any type of Combustibles in Existing Basement Areas is Prohibited.</p>	System Type: N/A	Demand:	Standpipe:	Demand:	Location:		<p>OPC Ed. 2011 OMC Ed. 2011 OPC Ed. 2011</p> <p>Health and Safety OBC Section 111.1</p> <p>Building Permit No: B13-000187</p> <p>Date: 06/12/2013</p> <p>Chief Building Official:  Michael J. Rudey</p>						
System Type: N/A	Demand:												
Standpipe:	Demand:												
Location:													

OCCUPANT LIMIT

99

Wood County Building Inspection
Per O.B.C. Section 1003

Brick & Brew Pub
631 North Perry, Napoleon Ohio 43545

Michael Rudey
Chief Building Official

Certificate of Occupancy

Wood County Building Inspection

Address:
 BRICK N BREW PUB
 631 NORTH PERRY
 NAPOLEON, OH 43545
 County: Henry

Stipulations, Conditions, & Variances:
 Interior Alterations. All Inspections Complete. Final Occupancy Approved.
 Maximum Occupancy 99.

Approved As:

Use Groups:	Occupancy Description:
Primary A-2	Bar/Restaurant
Accessory 0	
Accessory 0	
Accessory 0	
Mixed Use 0	

Attached Floor Plan:


Construction Type: 3B

Sprinklers

System Type: N/A Demand:
 Standpipe: Demand:

Location:
 Specific Hazards: Combustible Storage is Prohibited in the Existing Basement Areas.

This Certificate represents an approval that is valid only when the building and its facilities are used as stated and is conditional upon all building systems being maintained and tested in accordance with the applicable Ohio Board of Building Standards rules and applicable equipment or systems schedules. This certifies conformance with Chapters 3781 and 3791 of the Ohio Revised Code and the applicable provisions of the rules of the Ohio Board of Building Standards.

OBC Ed. 2011 OMC Ed. 2011 OPC Ed. 2011
 Health and Safety OBC Section 111.1
 Building Permit No: B13-000187
 Date: 07/25/2013
 Chief Building Official: 
 Michael J. Rudey