

CITY OF NAPOLEON

BUILDING CONSTRUCTION PERMIT

Owner Name Wm. SPANGLER
Address 713 N PERRY
Builder Name HAROLD BOSTELMAN ELECTRIAN
Address 618 PARK STREET Tel. 597-2323

Permit No. 34-A
Issued May 19 1972
By Robert P Jones Building Inspector
Estimated Cost \$300.00

Lot Information:

Street No. 713 N PERRY
Lot Subdivision
Lot Dimensions Lot Area Sq. Ft.
Yard Set Back: Front Rear
Side Side

Sidewalk required in accordance with Ordinance No.

Building Information:

Residence Commercial GROCERY STORE Industrial
Single Double Multiple New Construction Addition Remodel X
Size: Length Width No. of Stories
Floor Area: 1st Floor 2nd Floor 3rd Floor Basement
Unfinished Attic Garage
Foundation: Piers Full Basement Part Basement
Concrete Block
Walls: Frame Block Brick Other
Electrical Outlets: 120v 240v
Plumbing: Fixtures Traps Vents Heating Air Conditioning
Additional Information: BUILDING PERMIT # 34 ISSUED FOR NEW STORE FRONT ONLY 4-30-72

Table with 4 columns: Fees, Base, Plus, Total. Rows include Construction, Basement, Detached Garage, Plumbing, Electrical (5.00, .25, 5), Heating, Air Conditioning, Water Tap, Sewer Tap, Temporary Electric, Total (5.00, .25, 5.75).

Date Applicant Signature Owner - Builder - Agent

Inspection Record:

Work Started Foundations Plumbing, Heating
Set Back, Side Lines Plumbing (Rough In) And Air Conditioning
Excavation Erecting Frame Roof
Footing Electrical Work

Comments:

Certificate of Occupancy Issued

Pink - Engineer Inspector

CITY OF NAPOLEON

255 W. Riverview

NAPOLEON, OHIO 43545

message

reply

to:

Mr. Harold Bostelman

618 Park Street

Napoleon, Ohio 43545

subject ELECT. INSPECTION, SPANGLER'S GROCERY, PERMIT # 34-A

On Friday, July 19, 1974, an inspection was conducted on the new 200 amp., 3 phase entrance and the following conditions noted:

1. Strap the 2 1/2" entrance conduit to the support.
2. A ground wire is needed.
3. Install a fiber bushing and double lock nut at the point of conduit entrance into the breaker panel.

We also observed the general overall wiring of the basement area and do recommend that it be upgraded to the National Electrical Code Standards.

Copy to Fred Freppel

date July 24, 1974 signed R. H. Basselmann Building Commissioner

date _____ signed _____

SENDER: Mail white and pink copies with carbon intact.
33990, Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

RECEIVER: Reply, retain white copy, return pink copy.

CITY OF NAPOLEON
255 W. Riverview
NAPOLEON, OHIO 43545

message

reply

to:

MR. HAROLD BOSTELMAN

618 Park Street

Napoleon, Ohio 43545

subject ELECTRICAL INSPECTION; PERMIT #43-A
(Spangler's Grocery)

On Friday, July 26, 1974, an inspection was conducted on the electrical installation of the subject permit and the following conditions noted:

1. Remove the old entrance and all related parts.
2. AGAIN, secure the entrance conduit as stated in our July 19th. inspection.
3. The A/C compressor unit on the roof calls for a max. breaker size of 50 amps. The wiring to the unit is #8 THW on a 60 amp. breaker in the panel. The max. allowable breaker size is 45 amps on the afore stated wire size. THIS CONDITION MUST BE CORRECTED.

date 7/31/74

signed

R.H. Basselman
Bldg. Commissioner

date

signed

SENDER: Mail white and pink copies with carbon intact.
33990, Amsterdam Printing and Litho Corp., Amsterdam, N.Y. 12010

RECEIVER: Reply, retain white copy, return pink copy.

August 29, 1974

Mr. Harold Bostelman
618 Park Street
Napoleon, Ohio 43545

Re: Building Permit #34-A
Spangler's Grocery

Dear Mr. Bostelman:

During an inspection of 8-28-74, we observed that items 1 and 3 of our memo dated 7-31-74 have not been complied with or corrected. If this situation remains unattended we will take necessary action to force compliance. Another re-inspection will be conducted on Wednesday, September 4, 1974 to determine compliance or, if necessary, to take necessary action.

Also, we have had no communication as to the plans for upgrading the wiring of the basement area as per our memo of 7-24-74. Please do not have these items unattended.

Very truly yours,

R. H. Basselman, P.E.
Acting Building Commissioner

RHB/cv

cc: Mr. Fred Freppel
Mr. John Fruchey, Fire Captain