

CITY OF NAPOLEON, OHIO  
DIVISION OF BUILDING  
INSPECTIONS

Address of  
Property

812 PERRY

Date 7/21/80

Single \_\_\_\_\_ Two-Family \_\_\_\_\_ Apt. \_\_\_\_\_ Comm

Type of  
Inspection *Electric Plumb Heating*

Requested by:  
Name *J. O. TAPPY*

Address \_\_\_\_\_

Telephone \_\_\_\_\_

Permit No. \_\_\_\_\_

Excavation	ROUGH IN	Framing
Footers		Electrical
Footing Drains		Plumbing
Ext. Storm		Heating
Ext. Sanitary		Misc.
Int. Storm		
Int. Sanitary		
Foundation Final		Final

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_

Date 7/21/80 Inspector *R. J. ...*

INSPECTION REPORT

Re: 816 N. Perry - Commercial Building

An inspection was conducted on July 21, 1980 by John Fruchey and Richard Hayman for the occupancy of a building at 816 N. Perry. The following is a list of items that would have to be corrected before an occupancy certificate could be issued:

1. Center corridor shall have a fire resistance rating of one (1) hour on the walls and ceiling (5/8" drywall X rated meets a 1 hour fire rating).
2. All electrical circuits shall be in pipe.
3. All recepticals shall be grounded type.
4. Service to be 100 amps.
5. All circuits supplied by #14 AWG wire shall be no larger than 15 amps - #12 AWG wire shall be no larger than 20 amps.
6. Waiting area walls and ceiling shall be one (1) hour fire rated.
7. Doors leading from rooms to exit way shall be one (1) hour fire rated.
8. Interior door of all rooms shall be a minimum of 6 2/3 feet high and 32" wide.
9. Carpeting or resilient floors shall be flame resistant.

The above requirements are the minimum of the O.B.B.C. Code.

Richard G. Hayman  
Building Commissioner

*Class III  
Interior finish*