METER YOKE RELEASE

This document is for the release of **one (1)** Water Meter Yoke for Residential water service lines.

RELEASE NO. 147

PERMIT NO. _____ **ISSUED** 6-2-95

JOB LOCATION 822 N. Perry

(X) - **Inside City Limits** ( ) - **Outside City Limits**

ISSUED BY BNJ

OWNER John Hanna

ADDRESS 822 N. Perry

CONTRACTOR VonDeylen R&H

ADDRESS 116 E. Clinton

CONTRACTOR'S PHONE NO. 592-4756

WATER TAP SIZE: (X) = 1" ( ) = 1-1/2" ( ) = 2"

WATER METER s# _____

( ) - **New Dwelling** (X) - **Existing ~~Dwelling~~** Building

( ) - **Lawn Meter**

Water Service Line to be **Type (K) Copper or (CTS) Polyethelene Tubing of one inch (1") minimum.**

Watts No. 7 Dual check required (X) = Yes ( ) = No

Water Meter Yoke installation is subject to the following conditions:

1.) Must be located in an accessible area.

2.) Must be in an area not subject to freezing temperatures.

3.) Must be eighteen inches (18") above floor level, **not in crawl spaces.**

4.) Must comply with the mounting criteria and clearances as set forth in **DRAWING #04403901.**