

City of Napoleon

1032 S Perry

Fax Cover This is a confidential message, intended solely for the person to whom it is addressed. If you receive this message in error, please forward it to the correct person, or mail it back to us. Thank you.

To Lynnette Hablitzel - Ohio EPA NWDO
Fax No. (419) 352-8468
From Adam C. Hoff, P.E. - City Engineer *ACH*
Date 12/7/99
Subject Lutheran Home - Alpine Village Sanitary Sewer
Pages 1, including this one

The new sanitary sewer proposed for the Lutheran Home facility, 407 l.f. Of 10", will be pressure tested for a minimum of 8 minutes, 3 seconds, as per ASTM F1417. The City standard specifications will be modified accordingly, also.

If you have any questions, please call me at 592-4010. Thank you.

c: Mr. John Rosebrock - (419) 533-8704
Mr. Fred Berning - (419) 473-0506

255 W. Riverview Ave.
Napoleon, Ohio 43545

(419) 592-4010 Phone
(419) 599-8393 Fax