## City of Napoleon

## BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address.	10403	S Peirost	10		Zip:				
Business Name: B & B Plumbing & HVAC									
Contact Person:	Brian	TeiKI!		Title: Owner 5-22-98					
Phone Number:	533-396	1	Date of Test:	5-22-98					
DEVICE INFORMATION									
Type (circle one) RP DC VB RPDA DCDA									
Manf/Model: Watis 007M2-QT Size: 3/4 Serial No.: 116544									
Location of Device: Garage									
2.2000 and 2.	Differential Gauge								
Outlet	Reduced Pressure Assembly			Pressure Vacuum Breaker					
Valve	= 1 W-15 =								
Holding	Double Check Valv	e	Relief Valve	Air Inlet	Check Valve				
Failed	1st Check	2nd Check	4.4	- 7					
Test	DC 10.4 psi	DC 12 psi	Opened at	Opened at	Held at				
Results			psi	psi	psi				
	Apparent								
	RPpsi								
	Actual		Did Not	Did Not	Leaked				
	RPpsi		Open	Open					
Date: 5-22-94	Pass 4	Pass	Pass	Pass	Pass 🗆				
	Failed	Failed	Failed	Failed	Failed				
Repairs &									
Materials									
Materials	-								
			Onanad At	O	TT-1J AA				
Test After	DC psi	DC psi	Opened At	Opened At	Held At				
Repairs	psi psi	DCpsi	Did Not	psi Did Not	psi				
	RPpsi	RP psi	Open	Open	I nelsed				
	pai	psipsi	Open 🖾	Орен 🗀	Leaked				
Date:	Pass	Pass 🗍	Pass	Dags	Dono				
	1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1				Pass   Telled   Telled				
	tanks had	Tanco L	Failed	Failed	Failed				
Tester Signature: Brian Jeish Certification No. 411									
		March Min	1) hands	Cèrtification No.	31/				
Owner/Representative Signature: June 14/1 Dearlof Horages 13/									

## City of Napoleon

## BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address.	1040	S. Perry	下17		Zip:				
Business Name: B & Plumbine 3 HVAC									
Contact Person	Brian	Teikl		Title: Cwn e					
Phone Number	533-29	64	Date of Test:	5-22-98					
DEVICE INFORMATION									
Type (circle one)	1.00	(DC)	VB	RPDA	DCDA				
Manf/Model: Walts 007 M2 Size: 3/4 Serial No.: 124 608									
Location of Device: Garage									
	Differential Gauge		Sight Tube						
Outlet	Reduced Pressure Assembly		8	Pressure Vacuum Breaker					
Valve									
Holding	Double Check Valve		Relief Valve	Air Inlet	Check Valve				
Failed	1st Check	2nd Check							
	0. 1	el							
Test	DC 8.6 psi	DC 8,8 psi	Opened at	Opened at	Held at				
Results			psi	psi	psi				
	Apparent								
	RP psi								
	Actual		Did Not	Did Not	Leaked				
	RP psi		Open 🗆	Open					
Date:5-22-98	Pass	Pass /	Pass	Pass 🗆	Pass				
	Failed	Failed	Failed	Failed	Failed				
Repairs &									
Materials									
- Committee of the Comm									
			Opened At	Opened At	Held At				
Test After	DCpsi	DCpsi	psi	psi	psi				
Repairs			Did Not	Did Not	T.				
	RPpsi	RPpsi	Open	Open	Leaked				
					>				
Date:	Pass	Pass	Pass	Pass 🗆	Pass 🔲				
	Failed	Failed	Failed	Failed	Failed				
Dwner/Representative Signature: Sunda Managero BV									
Owner/Representative Signature: Sunda Managero BV									