

319 S. Perry St.

Date Installed:

4-11-02 ← North


Noel's Bar

Installed by:

Earl Elling,

Inspected by:

Rex Moll



Old 8" vit. tile seems to have a spot in line that is high, were hookup was made the 8" vit was still half way under water.

Williams

319 S. Perry St.

Date Installed:

4-11-02

← North


Noel's Bar

Installed by:

Earl Elling,

Inspected by:

Rex Moll



Old 8" vit. tile seems
to have a spot in line
that is high, were hookup
was made the 8" vit
was still half-ways
under water.

2/2/03

319 S. Perry St.

Noel's Bar

Date Installed:

4-11-02

← North

Installed by:

Earl Elling

Inspected by:

Rex Moll

4" Sch 40 pipe

4" x 6" Fernco with 6" wye and 6" x 4" F.L. 10.75' Deep

South-West corner of building

6" pl. to 8" cl. Fernco 10.5' Deep F.L.

Old 8" vit. tile seems to have a spot in line that is high, were hookup was made the 8" vit was still half ways under water.

2/2/02