



# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE - (419) 592-4010  
NAPOLEON, OHIO 43545-0151

Mayor  
Steven Lankenau

March 11, 1992

Members of Council  
Terri A. Williams, President  
John E. Church  
Michael J. DeWit  
Dennis L. Filgor  
Robert G. Heft  
James Hershberger

Mr. Tony Hovest  
Technicon, Inc.  
149 Court Street  
Ottawa, Ohio 45875

Re: Ottawa Oil Company  
Napoleon Party Mart

City Manager  
Terry Dunn

Dear Mr. Hovest:

This letter will act as our review of the site plans as submitted to our office on March 9, 1992.

Finance Director  
Rupert W. Schweinhagen

- (1) Although we have no control of the on-site drainage, we would like to see three (3) feet of cover on the storm sewer pipe.
- (2) The sidewalk shall be five (5) feet wide and its thickness shall be six (6) inches for a distance of five (5) feet both sides of driveway approach.
- (3) We are establishing the easterly radius point of the 5.5' radius of the East Maumee Street driveway approach to be five (5) feet from the property line. There currently does not exist a dimension.
- (4) Likewise, it is assumed that the dimension from the northerly property line to the northerly radius point of the Perry Street driveway is thirty-five (35) feet.

Law Director  
Michael J. Wesche

Prosecuting Attorney  
Thomas L. Bischoff

OK



# SIGN PERMIT

Permit No. 7D

Issued 7-13-69

By *[Signature]*

Estimated Cost \$400.00

Base Fee 4.00

Add 1.30

Total Fee \$405.30

Owner's Name *Henry O. Wendel Newcomb*

Address *330 S Perry St*

Builder *Harmon Sign*

Address *Nauseon, Ohio*

Tel. *333-2836*

SIGN

BILLBOARD

AWNING

MARQUEE

Location *SEW NW Cor Lot 142 Napoleon Original Division*

Dimensions

*4 x 3 1/2 = 13.5 sq ft 13 x 9 = 96*

Square Feet

*[Signature]*

Signature of Applicant

Application Must Be Accompanied with Sketch and Description of Proposed Installation

Please note that your contact person for inspection of utilities and right-of-way improvements is Sonny Helberg in the Engineers Office. We ask for twenty-four (24) hours notice prior to construction start-up.

Should you have any questions, please call.

Respectfully,



Marc S. Gerken, P.E.  
City Engineer

MSG:rw

cc: Sonny Helberg  
Brent Damman