

City of Napoleon

BACKFLOW PREVENTION ASSEMBLY TEST RESULTS

Property Address: 403 S. Perry Zip: 43545
 Business Name: Henry Co. Bank Southside
 Contact Person: Roger Murry Title: Maintenance
 Phone Number: 592-6700 Date of Test: 5-5-99

DEVICE INFORMATION

Type (circle one) **RP** **DC** **VB** **RPDA** **DCDA**
 Manf/Model: Watts 800 m4 Size: 1" Serial No.: 26746
 Location of Device: S.E. corner of Bldg.
 Type of Test Differential Gauge Sight Tube

| Outlet Valve | Reduced Pressure Assembly | | Pressure Vacuum Breaker | | |
|---|--|--|--|---|---|
| | Double Check Valve | | Relief Valve | Air Inlet | Check Valve |
| Holding <input checked="" type="checkbox"/> Failed <input type="checkbox"/> | 1st Check | 2nd Check | | | |
| Test Results Pass Date: <u>5-5-99</u> | DC _____ psi <u>Apparent</u> RP _____ psi <u>Actual</u> RP _____ psi | DC _____ psi | Opened at _____ psi Did Not Open <input type="checkbox"/> | Opened at <u>2.2</u> psi Did Not Open <input type="checkbox"/> | Held at <u>2.3</u> psi Leaked <input type="checkbox"/> |
| | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/> | Pass <input checked="" type="checkbox"/> Failed <input type="checkbox"/> |
| Repairs & Materials | | | | | |
| Test After Repairs Date: | DC _____ psi RP _____ psi | DC _____ psi RP _____ psi | Opened At _____ psi Did Not Open <input type="checkbox"/> | Opened At _____ psi Did Not Open <input type="checkbox"/> | Held At _____ psi Leaked <input type="checkbox"/> |
| | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> | Pass <input type="checkbox"/> Failed <input type="checkbox"/> |

Tester Signature: Bob [Signature] Certification No. 3016
 Owner/Representative Signature: Rodger Murry