

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT

255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01168 Issued May 23, 1986
date

Job Location 434 S. Perry St
address

Lot _____
sub-div or legal discript

Issued By Ron Lumentz
building official

Owner Craig Dille
name tel.

Address 434 S Perry St.

Agent Bostelman Electric 599-3416
builder-eng.-etc. tel.

Address 232 Rohrs St.

Description of Use New 100 A. Service

Residential one
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. _____ Alter _____ Remodel XX

Mixed Occupancy no

Change of Occupancy no

Estimated Cost \$500.00

N/A ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____

Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: New service and 8 circuits.
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____

Additional Information: _____

Date May 30 / 1986 Applicant Signature [Signature]
owner-agent

FEES	BASE	PLUS	TOTAL
BUILDING			
<input checked="" type="checkbox"/> ELECTRICAL	\$5.00	\$8.00	\$13.00
<input type="checkbox"/> PLUMBING			
<input type="checkbox"/> MECHANICAL			
<input type="checkbox"/> DEMOLITION			
<input type="checkbox"/> ZONING			
<input type="checkbox"/> SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs _____	Elect. _____ hrs _____	
TOTAL FEES.....			\$13.00
LESS MIN. FEES PAID _____ <small>date</small>			-0-
BALANCE DUE.....			\$13.00

PAID

MAY 30 1986

CITY OF NAPOLEON

PERMIT

CITY OF NAPOLEON - BUILDING DEPARTMENT
 255 West Riverview Avenue, Napoleon, Ohio 43545 - 419-592-4010

Permit No. 01168 Issued May 23 1986
date

Job Location 434 S. Perry St
address

Lot _____
sub-div or legal discript

Issued By Ross L. ...
building official

Owner Craig Dille
name tel.

Address 434 S Perry St.

Agent Bostelman Electric 599-3446
builder-eng.-etc. tel.

Address 233 Roars St.

Description of Use New 100 A. Service

Residential one
no. dwelling units

Commercial _____ Industrial _____

New _____ Add'n. _____ Alter _____ Remodel XX

Mixed Occupancy no

Change of Occupancy no

Estimated Cost \$ 500.00

FEES	BASE	PLUS	TOTAL
BUILDING			
ELECTRICAL	\$5.00	\$8.00	\$13.00
PLUMBING			
MECHANICAL			
DEMOLITION			
ZONING			
SIGN			
WATER TAP			
SEWER TAP			
TEMP. ELECT.			
ADDITIONAL PLAN REVIEW	Struct. _____ hrs	Elect. _____ hrs	
TOTAL FEES.....			\$13.00
LESS MIN. FEES PAID _____ <small>date</small>			-0-
BALANCE DUE.....			\$13.00

N/A ZONING INFORMATION

district	lot dimensions	area	front yd	side yds	rear yd
max hgt	no pkg spaces	no ldg spaces	max cover	petition or appeal req'd	date appr

WORK INFORMATION:

Size: Length _____ Width _____ Stories _____ Ground Floor Area _____
 Height _____ Building Volume (for demo. permit) _____ cu. ft.

Electrical: New service and 8 circuits.
brief description

Plumbing: _____
brief description

Mechanical: _____
brief description

Sign: _____ Dimensions _____ Sign Area _____
type

Additional Information: _____

Date May 30 / 1986 Applicant Signature [Signature]
owner-agent

PAID
 MAY 30 1986
 CITY OF NAPOLEON

CITY OF NAPOLEON
BUILDING INSPECTION DEPARTMENT
APPLICATION FOR ELECTRICAL PERMIT
(Please print or type)

The undersigned hereby makes application for installation or replacement of electrical equipment as herein specified, agreeing to do all such work in strict accordance with the City of Napoleon's adopted Electrical Codes.

Owner's Name Craig Dille Address 434 S. Perry

Electrical Contractor Bostelman Electric Telephone No. 599-3418

Address 232 Robrs ST.

General Contractor _____ Telephone No. _____

Address _____

Location of Project _____ Cost of Project _____

Work Information:

Residential 1 Commercial _____ Industrial _____
No. Units

New _____ Service Change X Rewiring _____ Additional Wiring 8 circuits

Brief Description of Work: New entrance & rewire house

Size of proposed service entrance 100 Number of new circuits 8 circuits

Type of proposed service entrance _____ Underground _____ Overhead X

Require Temporary Electric No (Yes or No)

Total Floor Area - Commercial and Industrial only _____ sq. ft.

Additional Information: _____

*Ground fault circuit interrupter protection is required on all 120-volt single phase, 15 and 20 amp. Circuits which are part of a temporary electric service; and also on bathroom, outdoor, and garage receptacles in all dwelling units. Art. 220-8 N.E.C.

*Application for permit shall be accompanied by two complete sets of plans including: Electrical layout and riser diagram. (For commercial and industrial work only).

Date, May 21, 1986

Applicant's Signature Norman P. Bostelman

PERMIT NO. 1168
PERMIT FEE \$ 13.00

