

CITY OF NAPOLEON  
Engineering Department  
APPLICATION FOR

STRUCTURAL PLAN APPROVAL  
(Please Print or Type)

DO NOT WRITE WITHIN BOXED AREA.  
FOR ENGINEERING OFFICE USE ONLY.

App. No. ~~444~~ 533-76

Date Received 6/1/76

Received By *Don W. Lorenora*

Estimated Cost

Minimum Fees

A. Structural

B. At Per 100 Ft.<sup>2</sup>

A. plus B. **NO FEES**

1. Owner's Name *Henry County*

Address *NAPOLEON, OHIO*

Tel.

2. Owner's Agent or Submitter

*Richard Bennett*

Address *RT. 5 NAPOLEON, OH*

Tel. *478-8187*

3. Plans Prepared By:

A. Architect *R.L. Pfotenhauer*

B. Engineer

C. Other

4. Name of Job and Description of Building, Store, Church, Etc.

*Shelter House Structure with Cooking Area*

5. Location of Project: *Henry County Fair Grounds* Zone: **"B"**

Lot # Subdivision Section

Yard Set Back: Front Rear

Side Side

6. Building Information:

Commercial Industrial New Construction

Addition Remodel

Size: Length *60* Width *40* No. of Stories *1*

Total Square Ft. Per Floor *2400*

7. Additional Information:

*Replacement of old Food Stand*

Signature of Applicant *Richard Bennett* Date *May 28, 1976*

White - Applicant Yellow - Clerk-Treasurer Pink - Engineering Gold - Plan Examiner

FORM OF PETITION/APPEAL

To: Engineering Department - City of Napoleon

For: Chairman and Members of Board of Zoning Appeals

I/We hereby file a petition/appeal for: (check the box applicable)

1.  Variance \$25.00  
2.  Conditional Use ~~\$25.00~~ NOT REQUIRED YEP,  
3.  Other As Applicable

(Print or type)

Describe the item checked and attach a site plan to scale if required and a ~~list consisting of names and addresses of property owners within 200' of the property requiring an appeal.~~

*Public and Recreational Facility.*

- Notes:
1. All petition/appeals require a minimum of 30 days notice for public hearing.
  2. Non-refundable filing fee to be paid full in advance.
  3. Petition/appeals to be filed in duplicate.
  4. Cost of publication and notices to be paid by the applicant.

Name and Address of Applicant

Box 39 RT. 5  
Napoleon, Ohio

Phone No. 498-8187

*Richard Bennett*  
Signature of Applicant

May 28, 1976  
Date

12/22/75 informed Rich Bennett of the below information,

ENGINEERING DEPARTMENT

INTEROFFICE COMMUNICATION

Date 12/22/75

To: Engineering

From: Tom To

Subject: Proposed 40' x 70' Outdoor Assembly Shelter

Located @: Fair Grounds

For: Fair Board - Sharon United Methodist Church

Contractor: Franklin Bennett

Type of Const: Pole Bldg, Wood Frame.

Classified Type IV-B Ordinary Const; Chapter BB-15

If Fire separation 30' or more Fire retardant wood or 1/2 hour min Noncombustible material.

- Roof system Less than 20' above floor combustible or Noncombustible material not protected.
- Chapter BB-65 Place of Outdoor Assembly (Outdoor Assembly Shelter)
- Not Less than 30' Fire separation for Type IV-B Const.
- CK'd with Zeller's (Health Dept) of higher requirements than BB-65-23, None.
- Min. of 1-water closet, 1-urinal, 1-Lavatorie for male. Min. of 2-water closets & 1-Lavatorie for female. Sec BB-65-23, Table BB-65-24
- Kitchen Area shall have not Less than Class "A" Finish for interior finish. Sec. 65-30

# City of NAPOLEON, OHIO

255 RIVERVIEW AVENUE — (419) 592-4010



**Mayor**

Robert G. Heft

**Clerk-Treasurer**

Rupert W. Schweinhagen June 11, 1976

**Members of Council**

Vern Holers, President

James Jackson

William Young

Earl Richardson

Lawrence Haase

David Strobel

Mr. Thomas W. Terranova  
Building and Zoning Inspector  
City of Napoleon  
P.O. Box 151  
Napoleon, Ohio 43545

SUBJECT: HENRY COUNTY FAIR GROUNDS  
SHELTER HOUSE STRUCTURE PLAN REVIEW

Dear Tom:

We are returning the drawings submitted for subject project for corrections and resubmittal.

The roof truss system selected by the Contractor is for a 20 foot wide structure which is not adequate for use on a 40 foot wide structure.

If you have any questions feel free to contact me at any time.

Very truly yours,

Robert C. Jones, P.E.  
Chief Enforcement Official

RCJ/fbh